



2/41

75
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No: F.6/DFS/MS/School/WZ/2023/ 63

Dated: 01/02/2023

FIRE SAFETY CERTIFICATE

Certified that the New Shalimar Public School located at BM Block (Pashcimi), Shalimar Bagh, Delhi – 110088, comprised of Ground + Mezzanine + One upper floor. Owned/occupied by New Shalimar Public School, was issued FSC vide letter No. F6/DFS/MS/WZ/School/2019/491 dated 08/03/2019. The premises was re- inspected by the officer concerned by this department on 19/01/2023 in the presence of Ms. Neetu Duggal (Principal) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the DOE Circular No. 262-362 dated 17/01/2005 and that the premises is fit for occupancy class “Educational” Group–B, with effect from 01.02.2023.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 Condition mentioned below.

Issued on 01.02.2023. at New Delhi.



(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Principal, New Shalimar Public School at BM Block (Pashcimi), Shalimar Bagh, Delhi – 110088.
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.


25/01/2023

INSPECTION REPORT

1. Name & address of the building : New Shalimar Public School Located at BM Block (Pashcimi), Shalimar Bagh, Delhi - 110088.
2. Type of Occupancy : Educational (Ground + Mezzanine + One upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/School/2019/491 dated 08/03/2019
5. Fire Safety directives letter No : DOE Circular No. 262-362 dated 17/01/2005
6. Date of inspection : 19/01/2023
7. Name of the Inspecting Officers : Sarabjeet Singh
8. Name and designation of officers from the building side : Ms. Neetu Duggal (Principal)
9. Year of Construction : 1987 (As per prv. insp. report dtd. 23/02/2019)
10. Applicant's letter No. : Outdoor dairy no. 9451 dated:- 26/12/2022

| |
|-----------------------------------|
| No. of Students = 280 |
| No. of class rooms = 17 |
| Plot area = 1130 m ² |
| Covered area = 680 m ² |

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | DOE Circular No. 262-362 dated 17/01/2005/As per prv. insp. report dtd. 23/02/2019 | Provided at site | Remarks MR/NMR | | | | | | | | | | | | | | | |
|----------------------------|---|---|------------------|--|----|----------------------------|-----------------|----|------------|----------|----|----|----|----|----|----|----|--|--|
| 1 | Access to building | | | | | | | | | | | | | | | | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Accessible</td> <td style="width: 40%;">16 m Provided</td> <td style="width: 30%;">MR</td> </tr> <tr> <td>Accessible</td> <td>420 cm Provided</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table> | Accessible | 16 m Provided | MR | Accessible | 420 cm Provided | MR | NA | NA | NA | | | | | | | | |
| Accessible | 16 m Provided | MR | | | | | | | | | | | | | | | | | |
| Accessible | 420 cm Provided | MR | | | | | | | | | | | | | | | | | |
| NA | NA | NA | | | | | | | | | | | | | | | | | |
| 2 | Number, Width, Type & Arrangement of Exits | | | | | | | | | | | | | | | | | | |
| | a. Number of staircases | | | | | | | | | | | | | | | | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">02</td> <td style="width: 40%;">03 Provided</td> <td style="width: 30%;">MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table> | 02 | 03 Provided | MR | NA | NA | NA | | | | | | | | | | | |
| 02 | 03 Provided | MR | | | | | | | | | | | | | | | | | |
| NA | NA | NA | | | | | | | | | | | | | | | | | |
| | b. Width of staircases | | | | | | | | | | | | | | | | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">1 x 1.50 mtr</td> <td style="width: 40%;">2 x 108cm & 1m (for mezzanine floor)(Iron Stair)</td> <td style="width: 30%;">MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table> | 1 x 1.50 mtr | 2 x 108cm & 1m (for mezzanine floor)(Iron Stair) | MR | NA | NA | NA | | | | | | | | | | | |
| 1 x 1.50 mtr | 2 x 108cm & 1m (for mezzanine floor)(Iron Stair) | MR | | | | | | | | | | | | | | | | | |
| NA | NA | NA | | | | | | | | | | | | | | | | | |
| | c. Protection of exits | | | | | | | | | | | | | | | | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">NR</td> <td style="width: 40%;">NR</td> <td style="width: 30%;">NR</td> </tr> <tr> <td>NR</td> <td>NR</td> <td>NR</td> </tr> </table> | NR | NR | NR | NR | NR | NR | | | | | | | | | | | |
| NR | NR | NR | | | | | | | | | | | | | | | | | |
| NR | NR | NR | | | | | | | | | | | | | | | | | |
| | e. No. of continuous staircases to terrace | 01 | Provided | MR | | | | | | | | | | | | | | | |
| | f. Width of Corridor | 1.5 mtr | 160 cm Provided | MR | | | | | | | | | | | | | | | |
| | g. Door Size | 1 mtr | 1 x 1.10 mtr | MR | | | | | | | | | | | | | | | |
| 3 | Compartmentation. | | | | | | | | | | | | | | | | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">NA</td> <td style="width: 40%;">NA</td> <td style="width: 30%;">NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table> | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | | |
| NA | NA | NA | | | | | | | | | | | | | | | | | |
| NA | NA | NA | | | | | | | | | | | | | | | | | |
| NA | NA | NA | | | | | | | | | | | | | | | | | |
| NA | NA | NA | | | | | | | | | | | | | | | | | |
| NA | NA | NA | | | | | | | | | | | | | | | | | |
| 4 | Smoke Management System. | | | | | | | | | | | | | | | | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">NA</td> <td style="width: 40%;">NA</td> <td style="width: 30%;">NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table> | NA | NA | NA | NA | NA | NA | | | | | | | | | | | |
| NA | NA | NA | | | | | | | | | | | | | | | | | |
| NA | NA | NA | | | | | | | | | | | | | | | | | |
| 5 | Fire Extinguishers | | | | | | | | | | | | | | | | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">11 nos.</td> <td style="width: 40%;">Provided</td> <td style="width: 30%;">MR</td> </tr> <tr> <td>CO₂, ABC type</td> <td>Provided</td> <td>MR</td> </tr> <tr> <td>ISI marked</td> <td>Provided</td> <td>MR</td> </tr> </table> | 11 nos. | Provided | MR | CO ₂ , ABC type | Provided | MR | ISI marked | Provided | MR | | | | | | | | |
| 11 nos. | Provided | MR | | | | | | | | | | | | | | | | | |
| CO ₂ , ABC type | Provided | MR | | | | | | | | | | | | | | | | | |
| ISI marked | Provided | MR | | | | | | | | | | | | | | | | | |

[Signature]

[Signature]

| | | | | |
|----|--|-------------------|----------|----|
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | 01 | Provided | MR |
| | • Length of hose reel hose | 30 mtr | Provided | MR |
| | • Nozzle diameter | 5 mm | Provided | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | Required | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | 100 mm | Provided | MR |
| | • Number of hydrants per floor | 01 | Provided | MR |
| | • Hose Box | 01 | Provided | MR |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | NA | NA | NA |
| | ➤ Head of Main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey Pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/ Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 450 lpm & 220 lpm | Provided | MR |
| | ➤ Head of the pump | 40 mtr | Provided | MR |
| | ➤ Power Supply | Required | Provided | MR |
| | ➤ Auto Starting of pump | Required | Provided | MR |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 5,000 ltrs | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |

| | | | | |
|----|--|----|----|----|
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | NA | NA | NA |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Batter backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/WZ/2022/283 dated 03/06 have been complied.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F.6/DFS/MS/WZ/2018/2550 dated 26/11/2018 renewal under DOE Circular No. 262-362 dated 17/01/2005 is recommended.

~~No (west)~~

[Signature]
20/01/2023

Signature of the Inspecting officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

[Signature]
20/11/2023

DCFO (WZ)

[Signature]
28/11/2023

~~ADO (MN)~~

Sir, F.T is put up for your kind personal & signature please.

DCFO (WZ)

[Signature]
28/11/2023

[Signature]
25/01/2023

next step

04/ADO/MN
20/01/2023

D.O. (M.N.)
DATED 20/01/2023