



No. F6/DFS/MS/2023/Ind./ 48

Dated: 01/02/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Ramble Cosmetic located at Plot No. B-36/1, G.T. Karnal Road, Industrial Area, Delhi-110033 comprised of ground & 03 upper floors but (industries is running in ground, first & second floors only) owned/occupied by M/s Ramble Cosmetic issued Fire Safety Certificate by this department vide this office letter no. F5/(3)/DFS/2008/136 dated 04.03.2008. The premise was re-inspection by the officer concerned of this department on 23.01.2023 in presence of Sh. Rajender Singh (Owner) and observed that all the fire prevention and fire safety arrangements as provided found in good working condition, premises have deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class G-2 "Industrial building" for ground, first & second floors only with effect from. 01/02/2023... for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .01/02/2023... at New Delhi by

(Dharmpal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. M/s Ramble Cosmetic located at Plot No. B-36/1, G.T. Karnal Road, Industrial Area, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. This Fire Safety Certificate is valid for ground, first & second floor only. If third floor use for any purpose this FSC will be treated as null & void.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
4. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of firefighting system.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate. six months prior to its expiry".

INSPECTION REPORT

| | |
|--|--|
| Name & address of the building | : Ramble Cosmetics Plot No.B-36/1, G.T.K. Road, Indl Area, Delhi-33. |
| Type of Occupancy | : Industrial Building |
| Composition of building | : Ground & 03 upper floors but Industry running at ground plus two upper floors only & third floor sealed by bricks wall |
| 4. Type of Case | : Renewal |
| 5. Details of previous NOC | : F5(3)/DFS/2008/136 dated: 04.03.2008 |
| 6. Fire Safety directives letter No | : Nil |
| 7. Date of inspection | : 23.01.2023 |
| 8. Name of the Inspecting Officers | : ADO(RN) |
| 9. Name and designation of officers from the building side | : Sh. Rajender Singh (Owner) |
| 10. Year of Construction | : Nil |
| 11. Applicant's letter No. | : Letter No. Nil & DFS Dairy No.9898 dated: 10.01.2023 |

Plot Area- 400Sqm.

| Minimum Standards on fire prevention and fire safety U/R 33 | | BBL-1983 Requirement | Provided at site | Remarks MR/NMR |
|---|---|----------------------|----------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 6m | 12m | MR |
| | • Gate width | 05m | 06m | MR |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 | 02 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.25m | 1.25m & 90cm | MR (old case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided | MR |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | 01 | 01 | MR |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | 01 m | 01m | MR |
| 3 | Compartmentation | | | |
| | • Fire check door | Required | Provided | MR |
| | • Sealing of electrical shafts | Required | Provided | MR |
| | • Fire Rating of shaft door | Required | Provided | MR |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | 12 a/c per hour | No basement | NA |
| | • Upper floors | 12 a/c per hour | Exhaust fan provided | MR |

| | | | | |
|----|--|--------------|---------------|-----|
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 20no's | 20no's | MR |
| | • Types | ABC/CO2 | ABC-16/CO2-04 | MR |
| | • ISI marking | ISI Marked | Provided | MR |
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | 01 | Provided | MR |
| | • Length of hose reel hose | 30m | Provided | MR |
| | • Nozzle diameter | 5mm | Provided | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | Smoke/ Heat | Provided | MR |
| | • Location of Main Panel | Ground floor | Provided | MR |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | Required | Provided | MR |
| | • Hooters' Location | Every floor | Provided | MR |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | Required | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • Upper Floor | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | 100mm | Provided | MR |
| | • Number of hydrants per floor | 01 | Provided | MR |
| | • Hose Box | 01 | Provided | MR |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey Pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |

| | | | | |
|----|---|------------|----------|-----|
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| MR | ➤ Auto Starting/ Manual stopping | N/A | N/A | N/A |
| MR | ➤ Pump House Access | N/A | N/A | N/A |
| M | • Terrace level | | | |
| | ➤ Discharge of pump | 450 LPM | 450 LPM | MR |
| | ➤ Head of the pump | 40m | 40m | MR |
| | ➤ Power Supply | Required | Provided | MR |
| | ➤ Auto Starting of pump | Required | Provided | MR |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | 10,000 LTR | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. One open goods lift is provided | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A | N/A | N/A |

N/10

The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 136 dated 04.03.2008 under rule 37 of the Delhi Fire Service Rules 2010.

Note:- The third floor found sealed by bricks wall at the time of inspection and an undertaking with photographs has been submitted by the management of the building and if any additional construction temporary or permanent is made, the FSC shall stand cancelled and shall be treated null and void. The same condition has been mentioned in the FSC.

Not use for any other purpose -

DO/NW — ON Leave

[Signature]
Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

~~Dy CFO (WZ)~~

[Signature]
01/11/2023

~~ADO/R-N~~

As approved, R.T. letter is put up for your signature R.

~~Dy CFO (WZ)~~

[Signature]
01/02/2023
~~ADO(RN)~~

[Signature]
01/11/2023

MS/ cell