

C-29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/CNG/2023/WZ/ 65

Dated: 07/02/2023

FIRE SAFETY CERTIFICATE

Certified that the **CNG Station at Khasra No. 487/2, Village- Tikri Kalan, District- West Delhi, Delhi-110041** comprised of **Ground Floor only (02 Nos. dispenser, 01 No. compressor & 01 No. Cascade at Ground floor)** owned/occupied by **M/s. Indraprastha Gas Limited**, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 24.01.2023 in the presence of Sh. Deepanshu (Technical, IGL.) and that the building/Premises is fit for occupancy "Hazardous Building" Group - J (**CNG Pump**) as above with effect from 07/02/2023 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 below.

Issued on 07/02/2023 at New Delhi by

W 7/2/2023
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Sh. Pulkit Bhardwaj Chief Manager (CNG PROJECTS), IGL Bawan, Plot no. 4, Community Centre, Sector-9, R.K. Puram, New Delhi-110022.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of authorized construction or alteration (Clause of 1.4.3 of UBBL-2016), if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	CNG Station at Khasra No. 487/2, Village - Tikri Kalan, Delhi-110041
2	Type of Occupancy	Hazardous "Group- J"
3	Type of Case	New (comprised of ground floor only & having 01 Compressor, 02 Dispenser & 01 Cascade at ground floor)
4	Details of Previous NOC	Nil
5	Fire Safety Directives Letter No	F6/DFS/MS/BP/2022/119 dated 17.03.2022
6	Date of Inspection	24.01.2023
7	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (JWP)
8	Name & Designation of Officers from the building side	Sh. Deepanshu (Technical, IGI)
9	Year of construction	2021-22
10	Applicant letter No.	IGI/CNGPRJ/NOC/03012023 dated 03.01.2023

S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NEPA/COE/OISD- etc. requirements	Provided at Site	Remarks NR/NMR
1	Access to Building.			
	• Road width	45 m	Provided	MR
	• Gate width	09 m	Direct accessible from road	-N/A-
	• Width of internal road	-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	-N/A-	-N/A-	-N/A-
	➤ Basement floor.	-N/A-	-N/A-	-N/A-
	b) Width of Staircase			
	➤ Upper floors	-N/A-	-N/A-	-N/A-
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	-N/A-	-N/A-	-N/A-
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	-N/A-	-N/A-	-N/A-
3	Compartmentation.			
	• Fire check door.	-N/A-	-N/A-	-N/A-
	• Sealing of electrical shafts.	-N/A-	-N/A-	-N/A-
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	-N/A-	-N/A-	-N/A-
4	Smoke Management system.			
	• Basement	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
5	Fire Extinguishers.			
	• Total numbers	Required	Provided	MR
	• Types	DCP, CO ₂ & Water mist cum foam trolley	DCP 75kg - 02, DCP 10kg - 13 & CO ₂ 4.5 kg -02, Trolley - 01	MR
	• ISI Marking	ISI marked	Provided	MR

Handwritten signature/initials

Handwritten marks

6.	First Aid Hose Reels.			
	• Total numbers on each floor	-N/A-	-N/A-	-N/A-
	• Length of hose-reel hose.	-N/A-	-N/A-	-N/A-
	• Nozzle Diameter	-N/A-	-N/A-	-N/A-
7	Automatic fire detection & alarming system.			
	• Gas and flame detectors in compressor packages area	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	• Basement.	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	-N/A-	-N/A-	-N/A-
	• Number of Hydrant per floor	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
12.	Yard Hydrants.			
	• Total number of hydrants.	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	• Ground Level			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• Terrace Level			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	-N/A-	-N/A-
	➤ Power supply.	-N/A-	-N/A-	-N/A-
	➤ Auto starting of pump.	-N/A-	-N/A-	-N/A-
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	-N/A-	-N/A-	-N/A-
15.	No Smoking Signage	Required	Provided in Hindi & English	MR

-N/A-
-N/A-
-N/A-

16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	-N/A-	Provided (DG Set)	-N/A-
18.	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	CO2 Flooding in compressor & 02 nos. Hand held explosive meter at Station	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards of fire prevention and fire safety requirements as per fire safety guidelines issued vide letter no. F6/DFS/MS/BP/2022/119 dated 17.03.2022, it is recommended to issue Fire Safety Certificate.

Accordingly DFA is put up for approval and signature please.

Aman Kumar Lathar
ADO (JWP)

D.O. (WEST) 577
DATED... 31/01/2023

DO (West)
31/01/2023
DO (West)
31/01/2023
CEO
21/01/2023
Director
21/01/2023
CEO
21/01/2023
FCO

F.F. letter is put-up for your signature pl.
Aman Kumar Lathar
07/2/23
ADO (JWP)