

C-29

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2023/WZ/School/84

Dated: 08/02/2023

FIRE SAFETY CERTIFICATE

Certified that the **D. V. Public School, F-205, Phase-I, Vijay Vihar, Rohini, Delhi-85**, comprised of **Ground + 03 upper floors (School is running on Ground + 02 upper floors) & 3rd floor not use** owner/ occupied **D. V. Public School** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2019/436 dated 26.02.2019**. The premises was re-inspected by the officer concerned of this department on **13.01.2023** in the presence of **Mr. Durgesh (Admin)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational "Group B" for Gr. + 02 upper floor only** with effect from 08/02/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/02/2023 at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, D. V. Public School, F-205, Phase-I, Vijay Vihar, Rohini, Delhi-85.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

N/18

INSPECTION REPORT

- Name & address of the building : D. V. Public School, F-205, Phase-I, Vijay Vihar, Rohini, Delhi-85
 Type of Occupancy : Educational
 Type of Case : Renewal (Ground + 03 upper floors)
 Details of Previous NOC : School is running on Gr. + 02 upper floors only
 Fire Safety directives letter No : F.6/DFS/MS/2019/436 dated 26.02.2019
 Date of inspection : NBC Part-IV
 Name of Inspecting Officer : 13.01.2023
 Name and designation of officers : A.K.Sharma ADO(Rohini)
 From the building side : Mr. Durgesh (Admin)
 Year of Construction : 2013 & 2016
 Applicant's letter No. : OD No.9537 dated 29.12.2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 4.5m NA	Accessible 4.0m NA	MR MR(Old case) NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 NA	04 NA	MR NA
	e. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.5m NA	1.35 to 1.5m & 1.10m(G to Terrace) & 1m & 1.20m (G to FF) NA	MR(Old case) NA
	f. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	NA Natural ventilated	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	12nos. ABC/CO2 ISI marked	15nos. ABC-15 Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 30mm 5m	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel 	NA NA	NA NA	NA NA

N/19

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		180lpm	180lpm	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450lpm	450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

Any

- Battery backup
- Building Floor Plans

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

NA

NA

NA

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 285 dated 03.06.2022, the FSC issued vide letter no. F.6/DFS/MS/2019/436 dated 26.02.2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

[Signature]
16/1/23

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

[Signature]
16/01/2023

Send it through to me.

Dy Cfo (W2)

[Signature]
21/1/2023

~~DO (NW)~~

Sir it was forwarded through me.

Dy Cfo (W2)

[Signature]
03/02/2023

[Signature]
03/02/2023

~~ADO Rohini~~

Fr letter is put up for kind
perusal and signature please.

Dy Cfo (W2)

[Signature]
27/1/2023

[Signature]
27/1/23

msf cell