

C-30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.


No.F.6/DFS/MS/School/2023/SZ/70

Dated: 07/02/2023

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya Vidyalaya, Hastal, New Delhi-110059, comprised of three blocks namely primary & old blocks having ground plus one floor only & New block having ground plus three upper floors, owned/occupied by Govt. of NCT of Delhi was issued FSC by this department vide letter No. F.6/DFS/MS/School/2018/SZ/689 dated 13/04/2018 (ground plus one upper floor). The School building was re-inspected by the officer concerned of this department on 30/01/2023 in the presence of Smt. Kiran Prabha (Principal) and found that the school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on...07/02/2023..... at New Delhi.

  
(Vinendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Principal, Govt. Sarvodaya Kanya Vidyalaya, Hastal, New Delhi-110059.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/15

**INSPECTION REPORT**

1 Name & address of the building : Govt. Sarvodaya Kanya Vidyalaya, Hastal, New Delhi-110059  
 2 Building comprised of : 3 blocks namely Primary & Old block (G+1) & New Block (G+3)  
 3 Type of Occupancy : Educational  
 4 Type of Case : Renewal/Addition  
 5 Details of Previous NOC : F.6/DFS/MS/School/2018/SZ/689 dated 13/04/2018  
 6 Fire Safety directives letter No : F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 & NBC  
 7 Date of inspection : 30/01/2023  
 8 Name of Inspecting Officer : A.D.O. R.K. Yadav  
 9 Name and designation of officers :  
 From the building side : Smt. Kiran Prabha (Principal)  
 10. Year of Construction : PB & OB-1993 & NB-2014  
 11. Applicant's letter No. : GSKV/H/2022 dated 20/12/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks
1.	<b>Access to building</b>			<b>MR/NMR</b>
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible 06 m 4.5 m N/A	09 m 05 m N/A	MR M/R N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	01 no. in PB, 02 no.'s in OB & 02 no.'s in NB	01 no. in PB, 02 no.'s in OB & 03 no.'s in NB	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	1.50 & .75 m	PB-1.50 m, OB-1.41 & 1.44 and NB-1.50, 1.50 & 1.41 m	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.50 m	1.55 m each in PB & OB and 1.80 m in NB	MR
	f. Door Size	1.0 m	PB & OB- 98 m (Single door) and NB 1.0 & 1.13 m (double door)	MR being old case
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	N/A	N/A	N/A
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	30 No's ABC/CO <sub>2</sub> type ISI marked	Provided Provided ISI marked	MR MR MR

AS      W      S      C



N/20

6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	02 Nos.	3 Nos.	M/R
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	Provided	M/R
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	05 mm	Provided	M/R
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	Provided	M/R
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Ground Floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>		<b>New Block</b>	
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	2 Nos.	3 Nos.	M/R
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	2 No.	3 Nos.	M/R
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	2 No.	3 Nos.	M/R
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump House Access</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>		<b>New Block</b>	
		450 LPM	Provided	M/R
		40 M	Provided	M/R
		Required	Provided	MR
		Required	Provided	M/R
14.	<b>Captive Water Storage for fire fighting</b>		<b>New Block</b>	
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Draw-off connection</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire service inlet</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Access to tank</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	10,000 Liters	10,000 Liters	MR
15.	<b>Exit Signage.</b>	Required	Provided	M/R

*[Handwritten signatures and initials]*

Provision  
Pre  
17.  
15.

N/21

**Provision of Lifts.**

(No Lift)

M/R	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
M/R		N/A	N/A	N/A
M/R		N/A	N/A	N/A
N		N/A	N/A	N/A
N		N/A	N/A	N/A
17.	<b>Standby power supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>&gt; Total Area</li> <li>&gt; Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued vide letter No.F.6/DFS/MS/School/2021/SZ/370 dated 27/07/2021 has been rectified. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter No. F.6/DFS/MS/school/2018/SZ/689 Dated 13/04/2018 renewal under the Rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*R.K. Yadav*  
11/2/2023

Signature of the Inspecting Officer  
Name- R.K. Yadav  
Designation- A.D.O (JKP)

DO(South West)

*ADP*  
21/2/23

*Dy. Insp (S2)*

*[Signature]*

*A.D.O (JKP)*

*C. F. O*  
3/2/2023

*Director*  
3/2/2023

*A.O/M/1*