

C-127

FORM 'II'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2023/ *School/76*

Dated: *08*/02/2023

**FIRE SAFETY CERTIFICATE**

Certified that building of **Modern Convent School**, Located at **Sector – 4, Dwarka New Delhi -110078** comprised of B + G + 04 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2021/415, dated-30/06/2021 (**Issued to G+3UF**) owned / occupied by **Modern Convent School** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the team of officers concerned of this department on 30/01/2023 in the presence of Dr. Sheetal Mann (Principal) and found that the said building is fit for occupancy class “Educational” Group B Sub Division B – 1 with effect from *08/02/2023* for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .... *08.02.2023* at New Delhi.

*Vu*  
*7/2/2023*  
(Virender Singh)  
Chief Fire Officer  
Delhi Fire Service.  
*etc*  
*h*

Copy to:

1. The Principal, Modern Convent School, Sector – 4, Dwarka New Delhi -110078.
2. Directorate of Education Old Secretariat Delhi – 110054.


**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building: Modern Convent School, Located at Sector - 4, Dwarka New Delhi -110078.
2. Type of Occupancy : Educational (Basement + Ground +4 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : F6/DFS/MS /2021 /415 Dated-30/06/2021  
**(Issued to Ground + 3 Upper Floors)**
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2004/2201 Dated 20/09/2004 ( **For B+G+3UFS**) & F6/DFS/MS/BP/2019/77 Dated 26/02/2019 ( **For B+G+4UFS**)
6. Date of inspection : 30/01/2023
7. Name of the Inspecting Officer :DO/SW & ADO (DWK)
8. Name and designation of Officer  
from the building side : Dr. Sheetal Mann (Principal)
9. Year of Construction : 2019-2020
10. Applicant's letter No. : Email Dated 24/01/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per NBC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	Provided	MR
	• Gate width	6 mtrs	Provided	MR
	• Width of internal road	6m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	06 Nos.	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	1.5m	1.86 , 1.66 , 1.79 , 2x150 & 1.37 m	MR
	• Basements	1.5m	1.5m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	01 mtr & 1.2m at 4 <sup>th</sup> Floor	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c charge per hour	Provided	MR
		12 a/c charge per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	4 nos.( At ABC & CO <sub>2</sub> ISI marked	43 Nos. DCP, CO <sub>2</sub> & Water Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	02 Nos. 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm 2 2	100 mm Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	Required Required	Provided Provided	MR MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	2280 lpm 88 M 01 180 lpm 40 m 2280 lpm 88 m Required Required 900 lpm 40Mtr Required Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided 40Mtr Provided Provided	MR MR MR MR MR MR MR MR MR MR MR MR MR



14.	Captive water Storage for fire fighting:			
	• Underground tank capacity	200000 ltr	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	25000 L	2x20000 ltr Provided	MR
	• Overhead Tank capacity			
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	Capsule lift provided	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	1. Detector system panel	NA	NA	NA
	2. Flow Switch Panel	NA	NA	NA
	3. PA System Panel	Required	Provided	MR
	4. Battery backup	Required	Provided	MR
	5. Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

*[Handwritten Signature]*  
30/1/23

Signature of the Inspecting Officer  
Name: Sh. Vedpal  
Designation: DO/SW

*[Handwritten Signature]*  
30/1/23

Signature of the Inspecting Officer  
Name: Udai Vir Singh  
Designation: ADO/DWK

*[Handwritten Signature]*  
30/1/23

*[Handwritten Signature]*  
2/2

*[Handwritten Signature]*  
30/1/23  
30/1/23  
30/1/23  
30/1/23  
30/1/23

*[Handwritten Signature]*  
DO/SW