

63

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2023/SZ/ 54

Dated: 08/02/2023

FIRE SAFETY CERTIFICATE

Certified that the Munde Distributors LLP (Restaurant) Located at Ground floor, RSM02, Plot No. 1, Sector-13, Dwarka, New Delhi in a building comprised of 03 tier basements, Ground + 3 Upper Floors was issued FSC vide letter No F6/DFS/MS/EH/2019/SZ/2233, dated 27/11/2019 & (F6/DFS/MS/2021/SZ/302, dated 07/07/2021 **To the Mall**) The premises was re - inspected by the officer concerned of this department on 24/01/2023 in the presence of Sh. Purushotam Maheswary (Cashier) and found the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Assembly" Group D with effect from 08/02/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on at New Delhi by.
08/02/2023


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Joint. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Manager, Munde Distributors LLP (Restaurant) Located at Ground floor, RSM02, Plot No. 1, Sector-13, Dwarka, New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement strictly shall be kept vacant as seen during inspection.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/9

INSPECTION REPORT

1. Name & address of the building: Munde Distributors LLP (Restaurant)
Located at Ground floor, RSM02, Plot No. 1, Sector – 13, Dwarka, New Delhi.
2. Type of Occupancy : Class-D (Assembly) (**Running At Ground Floor in a building comprised of 03 basement G + 03 UFs**)
3. Type of Case : Renewal
4. Details of previous NOC :F6/DFS/MS/EH/2019/SZ/2233, dated 27/11/2019 (To Restaurant) & F6/DFS/MS/2021/SZ/302, dated 07/07/2021 (**To the Mall**)
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2008/2140 Dated 28/07/2008
6. Date of inspection : 24/01/2023
7. Name of the Inspecting Officer ; Sh. Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Purushotam Maheswary (Cashier)
9. Year of Construction : Before 2015
10. Applicant's Letter No : Email dated-16/01/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/1, N/2 & N/3	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtrs	20 mtr	MR
	• Gate width	06 mtr	06 mtr	MR
	• Width of internal road	06 mtr	Provided (As per plan)	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	03 Nos.	NA
	• Basements	NA	09 Nos. + 01 Ramp	NA
	b. Width of staircases			
	• Upper floors	NA	02 mtrs	NA
	• Basements	NA	2.0/1.8/1.5 mtr + 1 Ramp 7.5 mtr (Two way)	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	2.40 m	2 m to 5 m	MR (Being old case)
	f. Door Size	2 mtr (2 Nos)	Provided	MR (Being old case)

N/10

3.	Compartmentation			
	• Fire check door	NA	Provided	NA
	• Sealing of electrical shafts	NA	Provided	NA
	• Fire Rating of shaft door	NA	Provided	NA
	• Water Curtain	NA	Provided	NA
	• Fire Dampers	NA	Provided	NA
4.	Smoke managements System			
	• Basements	NA	Provided	NA
	• Upper floors	12 a/c per hour	Natural Vent	MR
5.	Fire Extinguishers			
	• Total numbers	03 Nos.	Provided	MR
	• Types	ABC, CO2	ABC, CO2	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reel	Common with mall		
	• Total numbers on each floor	01 No	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	Ground floor	NA
	• Location of Repeater Panel	NA	Provided at ground floor	NA
	• Alternate source of power	NA	Battery Backup	NA
	• Hooters' Location	NA	Provided	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	NA	Provided	NA
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	Provided	NA
11.	Internal Hydrants: Common with mall			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	One	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	12 Nos.	NA
	• Hose Box	NA	Provided	NA

N/11

13.	Pumping Arrangements: Common with mall																																								
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	<table border="1"> <tr><td>NA</td><td>2850 lpm</td><td>NA</td></tr> <tr><td>NA</td><td>70 M</td><td>NA</td></tr> <tr><td>NA</td><td>02 Nos.</td><td>NA</td></tr> <tr><td>NA</td><td>280 lpm (2Nos),</td><td>NA</td></tr> <tr><td>NA</td><td>70 M</td><td>NA</td></tr> <tr><td>NA</td><td>2850 lpm</td><td>NA</td></tr> <tr><td>NA</td><td>70 M</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>900 lpm</td><td>Not Provided</td><td>MR (Pump at ground level at higher side)</td></tr> <tr><td>40 m</td><td>Not Provided</td><td>.....do.....</td></tr> <tr><td>Required</td><td>Not Provided</td><td>.....do.....</td></tr> <tr><td>Required</td><td>Not Provided</td><td>.....do.....</td></tr> </table>	NA	2850 lpm	NA	NA	70 M	NA	NA	02 Nos.	NA	NA	280 lpm (2Nos),	NA	NA	70 M	NA	NA	2850 lpm	NA	NA	70 M	NA	NA	Provided	NA	NA	Provided	NA	900 lpm	Not Provided	MR (Pump at ground level at higher side)	40 m	Not Provideddo.....	Required	Not Provideddo.....	Required	Not Provideddo.....
NA	2850 lpm	NA																																							
NA	70 M	NA																																							
NA	02 Nos.	NA																																							
NA	280 lpm (2Nos),	NA																																							
NA	70 M	NA																																							
NA	2850 lpm	NA																																							
NA	70 M	NA																																							
NA	Provided	NA																																							
NA	Provided	NA																																							
900 lpm	Not Provided	MR (Pump at ground level at higher side)																																							
40 m	Not Provideddo.....																																							
Required	Not Provideddo.....																																							
Required	Not Provideddo.....																																							
14.	Captive water Storage for fire fighting: Common with mall																																								
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	<table border="1"> <tr><td>NA</td><td>1,00,000 ltr</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>10000 ltr</td><td>Provided</td><td>MR</td></tr> <tr><td>Required</td><td>Provided</td><td>MR</td></tr> </table>	NA	1,00,000 ltr	NA	NA	Provided	NA	NA	Provided	NA	NA	Provided	NA	10000 ltr	Provided	MR	Required	Provided	MR																					
NA	1,00,000 ltr	NA																																							
NA	Provided	NA																																							
NA	Provided	NA																																							
NA	Provided	NA																																							
10000 ltr	Provided	MR																																							
Required	Provided	MR																																							
15	Exit Signage	Required	Provided																																						
16.	Provision of Lifts																																								
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	<table border="1"> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> </table>	NA	Provided	NA	NA	Provided	NA	NA	Provided	NA	NA	Provided	NA	NA	Provided	NA																								
NA	Provided	NA																																							
NA	Provided	NA																																							
NA	Provided	NA																																							
NA	Provided	NA																																							
NA	Provided	NA																																							
17.	Standby power supply	Required	Provided																																						
18.	Refuge Area																																								
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	<table border="1"> <tr><td>NA</td><td>NA</td><td>NA</td></tr> <tr><td>NA</td><td>NA</td><td>NA</td></tr> </table>	NA	NA	NA	NA	NA	NA																																	
NA	NA	NA																																							
NA	NA	NA																																							
19.	Fire control room																																								
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	<table border="1"> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> <tr><td>NA</td><td>Provided</td><td>NA</td></tr> </table>	NA	Provided	NA	NA	Provided	NA	NA	Provided	NA	NA	Provided	NA	NA	Provided	NA																								
NA	Provided	NA																																							
NA	Provided	NA																																							
NA	Provided	NA																																							
NA	Provided	NA																																							
NA	Provided	NA																																							

N/12

20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel.	MR
-----	--	----------	---	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/EH/2019/SZ/2233, dated 27/11/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~
 Name Uday Vir Singh
 Designation ADP/ADK

~~Signature~~

Signature
1/2/23 F.S.

Dy. Insp (S2)

Signature
2/2

~~Signature~~
(ADP/ADK)

Six FF letters is put up for of the

~~Signature~~
Dy Insp (S2)

~~Signature~~
3/2/23

~~Signature~~
09/2/23

Signature
6/2

M.S. (Signature)