

C-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.


No.F.6/DFS/MS/School/2023/SZ/ 67

Dated: 03/02/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building of Nagar Nigam Prathmik Bal Vidyalaya, (I & II Shift), Chaukhandi Old, New Delhi-110018, comprised of ground plus one upper floor, owned/occupied by Nagar Nigam Prathmik Bal Vidyalaya was issued FSC vide letter No. F.6/DFS/MS/School/2019/SZ/2324 dated 13/12/2019. The premises was re-inspected by the officer concerned of this department on 24/01/2023 in the presence of Smt. Manisha Nirmal (Incharge) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on..... 03/02/2023 ..... at New Delhi.



(Sunil Chawdhary)  
Dy. Chief Fire Officer

9/20

**Copy to:-**

1. The Principal,  
Nagar Nigam Prathmik Bal Vidyalaya, (I & II Shift),  
Chaukhandi Old, New Delhi-110018.
2. Director of Education,  
Civic Centre, Minto Road, New Delhi – 110002.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfn.delhi.govt.nic.in](http://www.dfn.delhi.govt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/14

**INSPECTION REPORT**

1. Name & address of the building : Nagar Nigam Prathmik Bal Vidyalaya.(I & II Shift),  
Chaukhandi Old, New Delhi-110018.
2. Type of Occupancy : Educational (G+1 upper floor only)
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2019/SZ/2324 dated 13/12/2019
5. Fire Safety directives letter No : DOE Dated-01/03/2011
6. Date of inspection : 24/01/2023
7. Name of Inspecting Officer : A.D.O. R.K. Yadav
8. Name and designation of officers  
From the building side : Smt. Manisha Nirmal
9. Year of Construction : 1962
10. Applicant's letter No. : Nil dated 03/01/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE- dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible Accessible N/A	06 mtrs 3.50 m N/A	M/R MR old case N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 no.'s N/A	Provided N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	2x1.5 m. N/A	1.73 m & 1.63 m N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
		01 no.	Provided	MR
	e. Width of Corridor	1.50 m	2.25 m	MR
	f. Door Size	1.0 m	2x 1.10 m	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N/A N/A	N/A N/A	N/A N/A
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	04 no.'s ABC/CO <sub>2</sub> type ISI marked	6 No.'s Provided Provided ISI marked	M/R M/R M/R

2/15

Exit Sign  
Provi  
Li

6.	<b>First-Aid Hose Reels</b>				
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	N/A	N/A	N/A	N/A
7.	<b>Automatic fire detection and alarming system</b>				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>				
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>				
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>				
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> </ul>	N/A	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump House Access</li> <li>Terrace level               <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A	N/A
14.	<b>Captive Water Storage for fire fighting</b>				
	<ul style="list-style-type: none"> <li>Underground tank capacity               <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A	N/A

19

W

N/16

	Exit Signage.	N/A	N/A	N/A
	Provision of Lifts.			
N/A	Lift)			(No
N/A	• Pressurization of Lift Shaft	N/A	N/A	N/A
N/A	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC was issued vide letter no F.6/DFS/MS/School/2019/S//2324 dated 13/12/2019 renewal under the Rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*R.K. Yadav*  
Signature of Inspecting Officer 24/11/2023

Name:- R.K.Yadav

Designation:- Asstt. Divisional Officer

D.O. (South West)

*24/11/23*  
*24/11/23*  
*24/11/23*  
*24/11/23*

*24/11/23*

*PP*