

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2023/Banquet/WZ/ 04

Dated: 03/02/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Urban Banquet A unit of Star Celebrations, Shop No.LGF1, Manglam Paradise Mall, Plot No.8, Manglam Place, Sector-3, Rohini, Delhi-110085, is running at Lower Ground floor building comprised of basement, ground + 05 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/2018/BNQT/2512 dated 12.11.2018. The premises was re-inspected by the officer concerned of this department on 18.01.2023 in the presence of Mr. Pramod Yadav and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Assembly for Lower ground floor only** with effect from 03/02/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/02/2023 at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : M/s Urban Banquet A unit of Star Celebrations, Shop No.LGF-1, Manglam Paradise Mall, Plot No.8, Manglam Place, Sector-3, Rohini, Delhi-110085.
2. Type of Occupancy : Assembly/Business
3. Type of Case : Renewal (Lower Ground floor only)
4. Details of Previous NOC : F.6/DFS/MS/2018/BNQT/2512 dated 12.11.2018
5. Fire Safety directives letter No : NBC Part-IV.
6. Date of inspection : 18.01.2022
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers From the building side : Mr. Pramod Yadav
9. Year of Construction : Old
10. Applicant's letter No. : Online application No.2022111820372 dated 21.11.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building [Manglam Paradise Mall, Plot No.8, Manglam Place, Sector-3, issued FSC vide letter No.F.6/DFS/MS/2022/WZ/282 dated 24.06.2022]			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Restaurant within Mall	As Above	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
	c. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> • Pressurization 	Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
	d. No. of continuous staircases to terrace	Restaurant within mall	As Above	MR
	e. Width of Corridor	Restaurant within mall	As Above	MR
	f. Door Size	2.0m	2.0m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
4.	Smoke Management System[Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Basements • Upper floors 	Restaurant within mall	As Above	MR
		12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers[Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	08nos.	10nos.	MR
		ABC/CO2	ABC-10	MR
		ISI marked	Yes	MR
6.	First-Aid Hose Reels[Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose 	01 near to restaurant	As Above	MR
		30mm	As Above	MR

M/12

	• Nozzle diameter	5m	As Above	
7.	Automatic fire detection and alarming system [Provided & Maintained by Mall management]			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	NA	As Above	NA
	• Location of Repeater Panel	NA	As Above	NA
	• Alternate source of power	NA	As Above	NA
	• Hooters' Location	NA	As Above	NA
8.	MOEFA			
		Required	Provided	MR
9.	Public Address System			
		Required	Provided	MR
10.	Automatic Sprinkler System [Provided & Maintained by Mall management]			
	• Basement	NA	As Above	NA
	• Ground & Upper Floors	NA	As Above	NA
	• Sprinkler above false ceiling	NA	As Above	NA
11.	Internal Hydrants [Provided & Maintained by Mall management]			
	• Size of riser/down-comer	100mm	As above	MR
	• Number of hydrants per floor	One(near to Restaurant)	As Above	MR
	• Hose Box	One(near to Restaurant)	As Above	MR
12.	Yard Hydrants [Provided & Maintained by Mall management]			
	• Total number of hydrants	Restaurant within mall	As Above	MR
	• Hose Box	Restaurant within mall	As Above	MR
13.	Pumping Arrangements [Provided & Maintained by Mall management]			
	• Ground Level	Restaurant within mall	As Above	MR
	➤ Discharge of main Pump	Restaurant within mall	As Above	MR
	➤ Head of Main pump	Restaurant within mall	As Above	MR
	➤ Number of main pumps	Restaurant within mall	As Above	MR
	➤ Jockey Pump out put	Restaurant within mall	As Above	MR
	➤ Jockey pump head	Restaurant within mall	As Above	MR
	➤ Standby Pump out put	Restaurant within mall	As Above	MR
	➤ Standby Pump Head	Restaurant within mall	As Above	MR
	➤ Auto Starting/Manual Stopping	Restaurant within mall	As Above	MR
	➤ Pump House Access	Restaurant within mall	As Above	MR
	• Terrace level	[Provided & Maintained by Mall management]		
	➤ Discharge of pump	NA	As Above	MR
	➤ Head of the pump	NA	As Above	MR
	➤ Power Supply	Required	As Above	MR
	➤ Auto Starting of pump	Required	As Above	MR
14.	Captive Water Storage for fire fighting [Provided & Maintained by Mall management]			
	• Underground tank capacity	Restaurant within mall	As Above	MR
	➤ Draw-off connection	Restaurant within mall	As Above	MR
	➤ Fire service inlet	Restaurant within mall	As Above	MR
	➤ Access to tank	Restaurant within mall	As Above	MR
	• Overhead Tank capacity	Restaurant within mall	As Above	MR
15.	Exit Signage.			
		Required	Provided	MR
16.	Provision of Lifts. [Provided & Maintained by Mall management]			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply			
		NA	NA	NA

Mej

X

As Above	> Total Area	NA	NA	NA
Mall management	> Location	NA	NA	NA
Provided	Fire Control Room [Provided & Maintained by Mall management]			
As Above	• Detector System Panel	NA	NA	NA
As Above	• Flow Switch Panel	NA	NA	NA
As Above	• PA System Panel	NA	NA	NA
As Above	• Battery backup	NA	NA	NA
As Above	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F.6/DFS/MS/2018/BNQT/2512 dated 12.11.2018** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

DO (WEST) 198
 DATED 24/10/2023

[Signature]
 24/11/23

Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)

~~DO (NW/SID)~~

[Signature]
 25/11/2023

[Signature]
 11/12/2023

~~ADO Rohini~~

FT letter is put up for kind
 perusal and signature please.

~~DeFO (W)~~

[Signature]
 27/11/2023

[Signature]
 27/11/23
 uploaded
 01/12/23
 (1)

not call