

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No.F.6 DFS/MS/School/2023/SZ/ 90

Dated: 09 / 02 / 2023

FIRE SAFETY CERTIFICATE

Certified that the **R. J Public School** located at L- Block, Street No-15, Mahipalpur Extension, New Delhi 110037 Comprised of Basement (closed) Ground plus Three upper floors (3rd Floor used as residence) owned/occupied by R. J Public School was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2017/SZ/1129 Dt. 28/07/2017. The said premises was re-inspected by officer concerned of this department on 03/02/2023 in presence of Sh. R. K Sagwan (Manager) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 09 / 02 / 2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 09 / 02 / 2023 at New Delhi by



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

Copy to: -

1. The Principal, R. J Public School located at L- Block, Street No-15, Mahipalpur Extension, New Delhi 110037
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT			
1	Name & Address of the Building	R. J Public School, L- Block, Street No - 15, Mahipalpur Extension, New Delhi 110037	
2	Type of Occupancy	Educational, Group-B (School)	
3	Building Comprised of	Basement, Ground plus Three Upper Floors.	
4	Type of Case	Renewal	
5	Details of Previous NOC	F6/DFS/MS/School/2017/SZ/1129 Dt. 28/07/2017	
6	Fire Safety Directives Letter No	DOE Circular Dated 01/03/2011	
7	Date of Inspection	03-02-2022	
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)	
9	Name & Designation of Officers from the building side	Sh. R. K Sagwan (Manager)	
10	Year of construction	2006 & 2011	Basement closed & 3 rd floor used as residence by the owner
11	Applicant letter No.	Outdoor diary no 8573 Dated 29/11/2022	
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site
1	Access to Building.		Remarks MR/NMR
	• Road width	Assessable	6 mtr
	• Gate width	-NA-	4.5 mtr
	• Width of internal road	-NA-	-NA-
2	Number, width, type & arrangement of exits.		
	a) Number of Staircase		
	➤ Upper floors.	01 No	02 No's
	➤ Basement floor.	-NA-	-NA-
	b) Width of Staircase		
	➤ Upper floors	1.50 m / 0.75 m	Provided
	➤ Basement floor	-NA-	-NA-
	c) Protection of exits		
	➤ Fire check door	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	01 Provided
	e) Width of corridor	-NA-	-NA-
	f) Door size	1 mtr	1 mtr
3	Compartmentation.		
	• Fire check door.	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-
	• Water curtain	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-
4.	Smoke Management system.		
	• Basement	-NA-	-NA-
	• Upper floors	12 ACPH	Provided
5.	Fire Extinguishers.		
	• Total numbers	Required	10 Nos
	• Types	ABC	ABC Type
	• ISI Marking	ISI mark	Provided
6.	First Aid Hose Reels.		
	• Total numbers on each floor.	One	Provided
	• Length of hose-reel hose.	30 m	Provided
	• Nozzle Diameter	5 mm	Provided
7	Automatic fire detection & alarming system.		

A m

N/17



<ul style="list-style-type: none"> • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
	-NA-	-NA-	-NA-	
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	ABC type fire extinguisher provided near elect. panel	MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 340 dated 23/06/2022.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2017/SZ/1129 Dt. 28/07/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Design: ADO (BCP)

6/12/2023

DO (South)

mmh
6/12/23

DO (S/P)

F. F.

AD (S/P)

As approved, F.T. letter is put up for your signature pl.

1/14
08/21/2023

Dy (S/P)

[Signature]

MS [Signature]