



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2023/NDZ/ 93

Dated: 10 / 02 / 2023

FIRE SAFETY CERTIFICATE

Certified that the **Deep Bharti Public School**, located at **B-2/642, St. No.-26, Harsh Vihar, Delhi-93**, building comprised of **G+1 Upper Floor only**, owned / occupied by Deep Bharti Public School, have complied with the fire prevention and Fire safety requirements in accordance with D.O.E. Circular No. F16/Estate/CC/Fire Safety/2011/ 3298-3398 Dated 01/03/11 and verified by the officer concerned of Fire Service on 30.01.2023 in presence of Sh. Tarun Tyagi (Manager) and that the building / premises is fit for occupancy class **"Educational" (Group B)** with effect from 10 / 02 / 2023 for a period of 3 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/02/2023 **at New Delhi by.**


(VIRENDER SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE.

Copy to:-

1. The Principal, Deep Bharti Public School, B-2/642, St. No.-26, Harsh Vihar Delhi-93.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Deep Bharti Public School, B-2/642, St. No. 26, Harsh Vihar, Delhi - 110093.
2. Building is comprised of : Earlier Ground Floor now G+1 Upper Floor (Addition/ Alteration)
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of previous NOC : F6/MS/DFS/2006/2255 Dated 29/08/2006 (For Ground Floor)
6. Fire Safety directives Letter No.: F.16/Estate/CC/FS/2011/3298-3398 Dt. 01/03/2011
7. Date of inspection : 30/01/2023
8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.)
9. Name and designation of Officer from the building side : Sh. Tarun Tyagi (Manager)
10. Year of Construction : 2006 -2021
11. Applicant's letter No. : Online Email dated 16/01/2023

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at Site	Remarks
1	Access to building			
	• Road width	Accessible	Accessible	M/R
	• Gate width	4.5 mtr	4.5 mtr	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 nos	02 nos	M/R
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1.50 m x 1	1.60 m & 1.40 m	M/R (Travel distance is meeting the requirement)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01	Provided	M/R
	e. Width of Corridor	1.50 mtr	1.50 mtr	M/R
	f. Door size	1.0 m	1.0 m	M/R
3	Compartmentation			
	• Fire check Door	N/A	N/A	N/A
	• Sealing of electrical Shafts	N/A	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
5	Fire Extinguishers			
	• Total Numbers	04 Nos.	04 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS Marking	ISI Marked	ISI Marked	MR

dtd

Seo

N/A

6	First-aid-Hose Reels			
	• Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false Ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of rise/down-comer	N/A	N/A	N/A
	• Number of Hydrants per Floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants			
	• Total number of Hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main Pumps	N/A	N/A	N/A
	➤ Jockey pump output	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump output	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto starting/Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage	N/A	N/A	N/A

05/20

N/A

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010 is recommended.

[Signature]
02/02/23

Signature of the Inspecting Officer
Name: Ashok Kumar Jaiswal
Designation: D.O. (East. Div.)

Dy. C.F.O. (N.D.2) Pl. spk.

[Signature]
DO (ED)

- Spoken

- Width of Staircases are 1.60 & 1.40 m. Board Distance is meeting the requirement with main staircase.

C.F.O. *[Signature]*
01/21/2023

[Signature]
08/02/23

Dy. C.F.O. (N.D.2)

[Signature]
09/02/23

DO (ED)

C.F.O.

[Signature]
01/21/2023

F.T. is added for

[Signature]
09/02/2023

RPW