

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/2023/SZ/college/06

Dated: 14/02/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **School of Language Literature & Culture Studies (SLL & CS)** Situated at JNU, New Delhi 110067 comprised of Ground Plus 03 upper floor, owned/occupied by Jawaharlal Nehru University was issued FSC by this department vide letter no F6DFS/MS/B/SZ/2019/638 dated 26/03/2019. The premise was re-inspected by the officer concerned of this department on 24/01/2023 in the presence of Sh. Ravinder Kumar and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy Class "**Education Building**" with effect 14/02/2023 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on... 14/02.../2023 at New Delhi by



**(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)**

Copy to:-

1. The Registrar, JNU, New Delhi 110067.
2. The Executive Engineer (Bldg), SDMC, Jal Vihar, Lajpat Nagar, New Delhi 110024



**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

## INSPECTION REPORT

1. Name & address of the building: School of Language Literature & Culture Studies (SLL & CS) at JNU  
Campus, New Delhi-67
2. Type of Occupancy : Group B (Educational)
3. Type of Case : Renewal
4. Comprised of : **Ground Plus 03 Upper Floors**
5. Details of Previous NOC : F6DFS/MS/B/SZ/2019/638 dated 26/03/2019
6. Fire Safety directives letter No : F6/DFS/MS/BP/2013/181 DATED 09/07/2013
7. Date of inspection : 24/01/2023
8. Name of Inspecting Officers : DO (SD) & ADO (BCP)
9. Name and designation of officers  
From the building side : Sh. Ravinder Kumar
10. Year of Construction : 2009
11. Applicant's letter No. : F. No. 4(322)/E/14-15/Vol-III/1632 dated 14/11/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	12 mtr -NA- 06 mtr	6m -NA- Provided (03 Side)	MR (old case) -NA- MR (old case)
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	02 Nos -NA-	2 No's -NA-	MR -NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basement</li> </ul>	1.50m -NA-	1.50m, -NA-	MR -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	Required -NA-	Provided -NA-	MR -NA-
	d. No. of continuous staircases to terrace	Required	2 No.	MR
	e. Width of Corridor	Required	1.50m,	MR
	f. Door Size	Required	1.0m (final exit)	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	Required Required -NA- -NA- -NA-	Provided Provided -NA- -NA- -NA-	MR MR -NA- -NA- -NA-
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	Required - Required	16 No's ABC/W.CO <sub>2</sub> -08/08 Yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	Required Required Required	2 Nos 30m 5mm	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-



8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground &amp; Upper Floors</li> <li>Sprinkler above false ceiling</li> </ul>	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
11.	Internal Hydrants	Required	100mm	MR
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	Required Required Required	02 Nos 02 Nos 02 Nos	MR MR MR
12.	Yard Hydrants	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-
13.	Pumping Arrangements	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level               <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 900 LPM 35 M Required Required	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- Provided 02 Nos Provided Provided Provided	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- MR MR MR MR
14.	Captive Water Storage for fire fighting	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Underground tank capacity               <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	-NA- -NA- -NA- Required 25,000 ltrs	-NA- -NA- -NA- Provided Provided	-NA- -NA- -NA- MR MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	-NA- -NA- Required Required Required	-NA- -NA- Provided Provided Provided	-NA- -NA- MR MR MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-
19.	Fire Control Room	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	-NA- -NA- Required Required	-NA- -NA- Provided Provided	-NA- -NA- MR MR
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

School of Language Literature & Culture Studies (SLL & CS) at JNU, New Delhi 110067

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6DFS/MS/B/SZ/2019/638 dated 26/03/2019, renewal under rule 37 (2) of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspection Officer  
Name: Sh. Manoj Kumar Sharma  
Design: DO (South)

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

Dy. CFO (SZ)

ADO (BCP)

As approved, F-7. letter is put up for your signature pl.

1/11/2023

Dy. CFO/2

M.S. AN