

C-9

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2023/99

Dated: 14/02/2023

FIRE SAFETY CERTIFICATE

Certified that the **Sona Memorial Public School, J-1/2/3, Main 70 Feet Road, Prem Nagar-II, Kirari Suleman Nagar, Delhi-110086**, comprised of **Ground + 03 upper floors** owned/ occupied by **Sona Memorial Public School** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on dated **18.01.2023** in the presence of **Mr. Joginder Singh** and that the building/ premise is fit for occupancy **Group B Educational** with effect from ...14/02/2023.. for a period of **three years**, in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/02/2023 at New Delhi by


(Virendra Singh)
Chief Fire Officer

Copy to:

1. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.
2. The Principal, Sona Memorial Public School, J-1/2/3, Main 70 Feet Road, Prem Nagar-II, Kirari Suleman Nagar, Delhi-110086.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms/

INSPECTION REPORT

1. Name & address of the building : Sona Memorial Public School, J-1/2/3, Main 70 Feet Road, Prem Nagar-II, Kirari Suleman Nagar, Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : New Case (**Ground + 03 upper floors**)
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : NBC Part-IV.
6. Date of inspection : 18.01.2023
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mr. Joginder Singh
9. Year of Construction : 2021
10. Applicant's letter No. : Online e-mail dated 03.11.2022.

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|--------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | 6.0m | 6.0m | MR |
| | • Gate width | 4.5m | 4.5m | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 | 02 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floor | 1.5m | 1.5m & 2.0m | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | 02 | 02 | MR |
| | e. Width of Corridor | 1.5m | 1.8m | MR |
| | f. Door Size | 1.0m | 1.10m | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke Management System | | | |
| | • Basements | 30 a/c per hour | NA | NA |
| | • Upper floors | 12 a/c per hour | Natural ventilated | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 14nos. | 15nos. | MR |
| | • Types | ABC/CO2 | ABC-15 | MR |
| | • IS marking | ISI marked | Yes | MR |
| 6. | First-Aid Hose Reels | | | |
| | • Total numbers on each floor | 02 | Provided | MR |
| | • Length of hose reel hose | 30mm | Provided | MR |
| | • Nozzle diameter | 5m | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |





| | | | | |
|-----|---|-----------|-----------|----|
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | NA | NA | NA |
| | • Ground & Upper Floors | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | NA | NA | NA |
| | ➤ Discharge of main Pump | NA | NA | NA |
| | ➤ Head of Main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey Pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/Manual Stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 450lpm | 450lpm | MR |
| | ➤ Head of the pump | 40m | 40m | MR |
| | ➤ Power Supply | Required | Provided | MR |
| | ➤ Auto Starting of pump | Required | Provided | MR |
| 14. | Captive Water Storage for fire fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 10,000ltr | 10,000ltr | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Battery backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |

**Special Fire Protection System for
Protection of special Risks, if any:**

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

24/11/23

W) $\frac{1}{2} \sqrt{4} D$

~~Add (Rehini)~~

27/1/8

Aug 35/1/23

~~By CFO (W2)~~

✓ 6/7/2013

CAF Wuehl
6/21/2023

07/02/2023

18/2/23

CFO 10/21/2023

FLW