

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**


No. F6/DFS/MS/School/SZ/2023/98

Dated: 14/02/2023

FIRE SAFETY CERTIFICATE

Certified that the Sukho Khalsa Sr. Sec. School, Jail Road, Janakpuri, New Delhi-110058, comprises of basement, ground plus one upper floor, owned/occupied by Sukho Khalsa Sr. Sec. School have complied with the fire prevention and fire safety requirements in accordance with Director of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398, Dated 01.03.2011 and verified by the officer concerned of this department on dated 09.02.2023 in the presence of Mrs. G. K. Thaper, Principal of the school and found that the building is fit for occupancy class B 'Educational Building' with effect from 14/02/2023 for a period of three years subject to compliance of the conditions mentioned below.

Issued on 14.02.2023 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal, Sukho Khalsa Sr. Sec. School, Jail Road, Janakpuri, New Delhi-110058.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.

Conditions for the validity of fire safety certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this FSC to Director in Form 'J' [Sub Rule (1) of Rule 37] along with a copy of this certificate, six month prior to its expiry.
8. This Fire Safety Certificate is not for Auditorium Block.

INSPECTION REPORT

1. Name & address of the building : Sukho Khalsa Sr. Sec. School, Jail Road, Janakpuri, New Delhi-110058.
2. Building is comprised of : B+G+1.
3. Type of Occupancy : Education
4. Type of Case : New Case
5. Details of Previous NOC : Nil.
6. Fire Safety direction letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398, Dated 01.03.2011
7. Date of Inspection : 09.02.2023.
8. Name of the Inspecting Officers: : Vedpal Chhikara(DO-SW)
9. Name and designation of Officer from the building side : Mrs. G. K. Thapar, Principal of the school.
10. Year of Construction : 1978
11. Applicant's letter No :No. SK/Fire Safety/23/389, Dated 06.02.2023

S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Circular dated 01.03.2011	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	Accessible	12m Provided	MR
	Gate width	4.5m	Provided	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	3nos.	4nos.	MR
	Basement	2nos.	02nos.	MR
	B. Width of Staircases			
	Upper Floor	1.50m/.75m	1.60m, 1.40m, 1.35m&1.30m	MR
	Basement	1.5m/.75m	1.60 & 1.20m	MR
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1no.	3nos.	MR
	g. Width of Corridor	1.5m	2m	MR
	h. Door Size	1m	1m	MR
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	Sealed	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	Required	Provided	MR
	Upper floor	Required	Natural Vent.	MR
5.	Fire Extinguisher			
	Total numbers	08nos. at each floor	Provided	MR
	types	CO ₂ & ABC	ABC Type	MR
	ISI marking	ISI marked	ISI marked	MR

N/12

6	First-aid-Hose Reels.			
	Total numbers of each floor	03nos.	03nos.	MR.
	Length of hose reel hose	30m	30m	MR.
	Nozzle diameter	5mm	5mm	MR.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	02nos.	02nos.	MR.
	➤ Discharge of pump	450+450LPM	Provided	MR
	➤ Head of the Pump	40m	40m each	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	15000 liters	15000 liters	MR
15	Exit Signage.	Required	Provided	MR.

h

h

n/13

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	Required	02 ABC type fire extinguishers provided near elect. panel	MR

The fire protection systems provided in the building were tested/ checked randomly and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety systems required under Director of Education circular No.3298-3398 dated 1.03.2013. It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Accordingly, DFA is put up.

Note: The Auditorium block is sealed and not in use and not considered for fire safety certificate.

Signature of the Inspecting Officer

Name Vedpal Chhikara

Designation DO(SW)

Dy.CFO(SZ)

G.F.O. - Mug
10/21/2023

DO(SW)

FT letter is put up for sign h/f

CFO/DFS Mug
13/21/2023

FAW

h/f
13/21/23
DO(SW)