

C. 81

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**


No.F6/DFS/MS/EH/NDZ/2023/BNQT/05

Dated : 13/02/2023

FIRE SAFETY CERTIFICATE

Certified that the **Dream Heritage Banquet** located at **882, East Park Road, Karol Bagh, Near Ajmal Khan Park, Karol Bagh, New Delhi** comprises of **Basement + Ground + 03 Upper floor, Banquet hall at ground floor only** owned/occupied by Dream Heritage Banquets, was granted FSC by this department vide letter No.F6/DFS/MS/EH/2019/2056 dated **25/10/19**. Now, the premises was re-inspected by the officer concerned of this department on **03/02/23** in the presence of Mr. Abhishek, Caretaker and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building (Group D) for ground floor banquet only** with effect from **13/02/2023** for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued .. **13/02/2023** .. at New Delhi by.


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner , MCD , Civic Centre, New Delhi
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi online id no. 2023012000898 dated 20/01/23.
3. The Manager, Dream Heritage Banquets, 882, East Park Road, Karol Bagh, Near Ajmal Khan Park, Karol Bagh, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. This NOC is valid only for ground floor.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

1124
INSPECTION REPORT

1. Name & address of the building Dream Heritage Banquet at 882, East Park Road, Karol Bagh, Near Ajmal Khan Park, Karol Bagh, New Delhi
2. Type of occupancy:- Assembly Building Group-D
B + Gr. + 03 upper floors, Banquet hall at ground floor only
Basement (Storage), Ground floor (Banquet hall),
1st floor to 3rd floor (others property).
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/NDZ/2019/2056 dated
25/10/19
5. Fire safety directives No.- N/A
6. Date of inspection:- 03/02/23
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer from the building side:- Mr. Abhishek , care taker
9. Year of construction:-
10. Applicant's letter No:- Online Id 2023012000898 dated 20/01/23.

Old case

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement As per NBC part - IV | Provided at site | Remarks MR/NMR |
|-----------|---|----------------------------------|---|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | 09 mtr | 12 mtr. | MR |
| | 2) Gate width | N/A | N/A | N/A |
| | 3) Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | N/A | N/A | N/A |
| | 2. Basements | N/A | N/A | N/A |
| | B. Width of staircase | | | |
| | 1. Upper floors | N/A | N/A | N/A |
| | 2. Basements | N/A | N/A | N/A |
| | C. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | | | |
| | N/A | | | |
| | E. Width of corridor | | | |
| | N/A | | | |
| | F. Door size | | | |
| | 2 mtr. | | 2.4 mtr., 2.0 mtr., 1.45 mtr. & 1.03 mr. | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements | 30 ACPH | N/A | N/A |
| | 2) Upper floors | 12 ACPH | Natural | MR |
| 5. | Fire Extinguishers | | | |
| | 1) Total numbers | 06 Nos. | 06 Nos. | MR |
| | 2) Types | ABC & CO2 | ABC & CO2 | MR |

M/25

| | | | | |
|------------|---|----------|------------|-----|
| | 3) ISI marking | Required | Provided | MR |
| 6. | First-Aid Hose Reel | | | |
| | 1) Total number of each floor | 01 | 01 ✓ | MR |
| | 2) Length of hose reel hose | 30 mtr. | 30 mtr. | MR |
| | 3) Nozzle diameter | 05 mm | 05 mm | MR |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors (smoke) | Required | Provided ✓ | MR |
| | 2) Location of main panel | Required | Provided ✓ | MR |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | Required | Provided | MR |
| | 5) Hooter's Location | Required | Provided | MR |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | N/A | N/A | N/A |
| | 2) Upper floors | N/A | N/A | N/A |
| | 3) Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | 100 mm | 100 mm ✓ | MR |
| | 2) Number of hydrants per floor | 01 | 01 ✓ | MR |
| | 3) Hose box | 01 | 01 | MR |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | | | |
| | a) Discharge of main pump | N/A | N/A | N/A |
| | b) Head of main pump | N/A | N/A | N/A |
| | c) Number of main pump | N/A | N/A | N/A |
| | d) Jockey pump out put | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 2) Terrace level | | | |
| | a) Discharge of pump | 450 LPM | 450 LPM ✓ | MR |
| | b) Head of pump | 30 mtr. | 30 mtr. ✓ | MR |
| | c) Power supply | Required | Provided | MR |
| | d) Auto starting of pump | Required | functional | MR |
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | N/A | N/A | N/A |
| | a) Draw-off connection | N/A | N/A | N/A |

W


n/26

| | | | | |
|-----|---|-------------|---------------|-----|
| | b) Fire service inlet | N/A | N/A | N/A |
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | 10,000 ltr. | 10,000 ltr. ✓ | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | N/A | N/A | N/A |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: ABC & Co2 | | | MR |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F6/DFS/MS/EH/2019/2056 dated 25/10/19 renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer



Name: - Ravinder Singh
Designation - ADO(CC)

Dy. Insp

7/2/23

Dy. Insp (CC)

F.T. please.

8/2/23

ADO(CC)

As approved, RT is put up for
kind perusal and signature please.

Dy. Insp (CC)

10/2/23

F.P. wing

15/2/23

9/2/23