



C-78

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/NDZ/2023/ 60

Dated: 15/02/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Chirag Foods located at C-31-32, No. 11, Madhu Vihar, Delhi-110092, building comprises of Basement (Storage), Ground Floor (Restaurant), First Floor (Kitchen), Second Floor (Residence) owned/occupied by M/s Chirag Foods, was earlier issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2019/NDZ/25 Dated 13/01/2020. The premises was re-inspected by the officer concerned of this department on 07/02/2023 in the presence of Sh. Kamal Kumar Gupta and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "**Assembly Restaurant (Group D)**" with effect from 15/02/2023 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 15/02/2023 **at New Delhi by**

(S.K. DUA)

DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE.

Copy to:

1. Sh. Kamal Kumar Gupta M/s Chirag Foods C-31-32, No. 11, Madhu Vihar, Delhi-110092.
2. The Joint Commissioner of police (Lic) P.S: defence colony, New Delhi-24. w.r.t. **Online Application ID no. 2023012000865 Dated 25/01/2023.**

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
 2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
 3. The trained fire fighting staff should be available round the clock.
 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
 6. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
 7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [subrule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
 8. The gas cylinder if used in the kitchen shall be as per gas cylinder rules only.
- 3/6

1. Name & address of the building : M/s Chirag Foods, C-31-32, No. 11, Madhu Vihar, Delhi-110092
2. Building is comprised of : B+G+2 upper floor only (Restaurant at Ground floor only)
3. Type of Occupancy : Assembly building (Restaurant)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/EH/2019/NDZ/25 dt13/01/20
6. Fire Safety directive letter No : NBC Part IV
7. Date of Inspection : 07/02/2023
8. Name of the Inspecting officers : A.K.Jaiswal D.O.(E.D)
9. Name and designation of Officer from the building side : Mr. Kamal Kumar Gupta, (Owner)
10. Year of Construction : 2001
11. Applicant's letter No : 2023012000865 Dated 25/01/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 06 mtr. N/A N/A 	<ul style="list-style-type: none"> 10 mtr. N/A N/A 	<ul style="list-style-type: none"> M/R N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor 	N/A	02	N/A
	<ul style="list-style-type: none"> • Basement 	N/A	02	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor 	N/A	2 m (Ground & First Floor) & 1.15 m	N/A
	<ul style="list-style-type: none"> • Basement 	N/A	2.00 m & 1.50 m	N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Pressurization 	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	2	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2.00 m	2.00 m x 2	M/R
	g. Number of Door	N/A	N/A	N/A
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> Provided N/A 	<ul style="list-style-type: none"> N/A N/A
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 06 ABC /CO₂ ISI marked 	<ul style="list-style-type: none"> 06 ABC /CO₂ Provided 	<ul style="list-style-type: none"> M/R M/R M/R

AKJ


06	First-Aid-Hose Reels	01	Provided	M/R ✓
	Total numbers on each floor Near restaurant		Provided	M/R ✓
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	
07	Automatic Fire Detection and Alarming System			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	Provided	N/A
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of nser/down-comer	100 mm	100 mm	MR ✓
	• Number of hydrants per floor	01	01	MR ✓
	• Hose box	01	01	MR
12	Yard Hydrants			
	• Total number of hydrants	N/A	Provided	MR
	• Hose box	N/A	Provided	MR
13	Pumping Arrangements			
	> Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	> Terrace Level			
	• Discharge of pump	900 LPM	900 LPM	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	20,000 ltr	20,000 ltr	MR
		Required	Provided	MR
15	Exit Signage			

[Handwritten signature]

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view, of the deemed compliance of the minimum standards of Fire Prevention and Fire Safety measures as required under the rules the NOC/FSC issued vide letter No. F.6/DFS/MS/EH/2019/NDZ/25 dated 13/01/20 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name : A.K. Jaiswal
 Designation : DO (ED)

~~Dy. CFO (NDZ)~~

F.T. please.

Living
10/02/23

DO (ED)

As Approved, F.T. is added for sign-fl.

~~Dy. CFO (NDZ)~~

Living
15/02/23

APJ
13/02/23

F.P. wing

Unloaded
17/02/23