

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/CNG/2023/SZ/ 105

Dated: 27/02/2023

FIRE SAFETY CERTIFICATE

Certified that the CNG Station at Khasra No. 9/24 (6-3), Village- Baprola (Chanchal Park), Nangloi- Najafgarh Road, west Delhi, Delhi-110043, comprised of ground floor only, (04 Dispenser) owned/occupied by Indraprastha Gas Limited. The premise was inspected by the officer concerned of this department on 08/02/2023 in the presence of Sh. Sethi (Manager) and found that CNG Dispensing Station have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises (CNG Dispensing Station) is fit for occupancy Class "J" Hazardous Building w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....27/02/2023.....at New Delhi.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

Sh. Pulkit Bhardwaj (Chief Manager),
Indraprastha Gas Limited, IGL Bhawan, Plot No.-4,
Community Centre, Sector-9, R.K.Puram, New Delhi-110022

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

Name & address of the building : CNG Station at Khasra No. 9/24 (6-3), Village- Baprola (Chanchal Park), Nangloi- Najafgarh Road, West Delhi, Delhi-110043.

Building comprised of : CNG dispensing station is at Ground floor only.

2. Type of Occupancy : Group "J" Hazardous

3. Type of Case : New

4. Details of Previous NOC : N/A

5. Fire Safety directives letter No : F.6/DFS/MS/BP/CNG/2022/336 dated 19/07/2022

6. Date of inspection : 08/02/2023

7. Name of Inspecting Officer : A.D.O. R.K.Yadav

8. Name and designation of officers from the building side : Sh. Sethi (Manager)

9. Year of Construction : 2022

10. Applicant's letter No. : IGL/CNGPRJ/NOC/03012023 dated 03/01/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NFPA/CCOE/OISD etc. requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09 m NA NA	Provided Directly accessible from road NA	MR NA NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	NA NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	14 no.'s Required ISI	Provided 7 Nos. DCP Type (9 kg), 2 Nos. CO2 Type 4.5 kg, 5 Nos. DCP Type (75 kg) trolley mounted Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Gas and flame detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Required	Provided	MR
		NA	Office at GF	NA
		NA	NA	NA
		Required	Provided	MR
		NA	At station	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Ground Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access <ul style="list-style-type: none"> • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA

NYC

Provision of Lifts.

	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	CO ₂ flooding system in compressor	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

Note: Sand buckets are provided in the premises & No smoking boards adequately displayed in English and Hindi.

Advance fire water mist cum foam trolley is provided.

Two hand held explosive meters are also provided.

P. K. Yadav

Signature of Inspecting Officer 14/2/2023

Name:- R.K.Yadav

Designation:- Asstt. Divisional Officer

Divisional Officer (South-West)

Sunil Choudhary
16/2/23

Sunil Choudhary
CFO (P.A.)

[Signature]
17/2

[Signature]
CFO (P.A.)

[Signature]
11/2/2023

[Signature]
Director

[Signature]