

C-191

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2023/ School/147

Dated: 28/2/2023

FIRE SAFETY CERTIFICATE

Certified that the building of ITL Public School Located at Sector – 09, Dwarka, New Delhi - 110077 comprised of Basement + G+3 UFS was issued FSC vide letter No. F6/DFS/MS/School/2020/SZ/53, dated 12/02/2020. The premises was re inspected by the officer concerned of this department on 20/02/2023 in the presence of Mr. Rajan S Rautela (Estate Manager) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class B “Educational building” with effect from 28/02/2023 for a period of three years. In accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/02/2023 at New Delhi by.



(Sunil Chaudhary)
Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Principal, ITL Public School Located at Sector – 09, Dwarka, New Delhi - 110077.
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: ITL Public School Located at Sector-09, Dwarka, New Delhi - 110077.
2. Type of Occupancy : Educational (Basement + Ground+ 3 Upper Floors)
3. Type of Case : Renewal (**Both blocks are interconnected at 2nd & 3rd floor**)
4. Details of previous NOC : F6/DFS/MS/School/2020/SZ/53, dated 12/02/2020
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2000/1862 dated 09/10/2000
6. Date of inspection : 20-02-2023
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side: Mr. Rajan S Rautela (Estate Manager)
9. Year of Construction : 2012 New 2019,20
10. Applicant's letter No. : BBIS/DW/MCD/2023/429, dated 14/01/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/14, N/15 & N/16	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos. each block	Provided	MR
	• Basements	02 Nos. each block	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr & .75m	Provided Old case	MR (Being old case)
	• Basements	1.5 mtr & .75m	Provided Old case	MR (Being old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	1.5 m	NA
	f. Door Size	01 mtr	Provided	MR (Being old case)
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA




4.	Smoke managements System				
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c charge	Exhaust fans provided	MR	
		12 a/c charge	Natural ventilation	MR	
5.	Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers Types IS marking 	01 for every 300 sq.mtr ABC & CO ₂ ISI marked	Provided Provided ISI marked	MR MR MR	
6.	First-Aid Hose Reels				
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 Nos. each block	Provided	MR	
		30 mtr	Provided	MR	
		05 mm	Provided	MR	
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
8.	MOEFA	NA	NA	NA	
9.	Public Address System	NA	NA	NA	
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required	Provided	MR	
		NA	NA	NA	
		NA	NA	NA	
11.	Internal Hydrants:				
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	100 mm	NA	
		NA	02	NA	
		NA	Provided	NA	
12.	Yard Hydrants				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	04 Nos.	NA	
		NA	04 Nos.	NA	
13.	Pumping Arrangements:				
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	2280 lpm	NA	
		NA	70m	NA	
		NA	1	NA	
		NA	180 lpm	NA	
		NA	70m	NA	
		NA	2280 lpm	NA	
		NA	70 m	NA	
		NA	Provided	NA	
		NA	Provided	NA	
		900 LPM	Provided	MR	
		40 mtr	Provided	MR	
		Required	Provided	MR	
		Required	Provided	MR	




4/20

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	50,000 ltr	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	15,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	NA	DG Set	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC & CO2 fire extinguisher provided near electric meter	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2020/SZ/53, dated 12/02/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended

Signature of the Inspecting Officer
Name
Designation

[Signature]
21/2/23
Uday Vir Singh
ADO/DW

[Signature]
24/2/23
Sukil Choudhary CFO

[Signature]
m.s. *[Signature]*