

c-16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/School/WZ/2023/ 146

Dated: 28/02/2023

FIRE SAFETY CERTIFICATE

Certified that the **M. C. Primary School, R-1, Mangol Puri, Rohini Zone, Delhi-83**, comprised of **Ground + 01 upper floors** owned/ occupied by **M. C. Primary School** have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on **14.02.2023** in the presence of **Mr. Om Prakash Meen (Principal)** and that the building/ premise is fit for occupancy **Group B Educational** with effect from 28.10.2023 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 28/02/2023 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000
etc
Ch

Copy to:

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, M. C. Primary School, R-1, Mangol Puri, Rohini Zone, Delhi-83.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : M. C. Primary School, R-1, Mangol Puri, Rohini Zone, Delhi-83.
2. Type of Occupancy : Educational
3. Type of Case : New Case (Ground + 01 upper floor)
4. Details of Previous NOC : N/A
5. Fire Safety directives letter No : Director of Education Cir. dated 01.03.2011.
6. Date of inspection : 14.02.2023
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mr. Om Prakash Meen (Principal)
9. Year of Construction : 2006
10. Applicant's letter No. : Online e-mail dated 06.02.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	Accessible	MR
		Accessible	Accessible	MR
		NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02	02	MR
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.5m or two staircases of less than 1.5m	1.40m	MR(Old case)
		NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	All class rooms are double door	MR ✓
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06nos.	06nos.	MR
		ABC/CO2	ABC-06	MR
		ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

	<ul style="list-style-type: none"> • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Ground & Upper Floors • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel 	NA	NA	NA
		NA	NA	NA

Avg ✓ ~

- PA System Panel
- Battery backup
- Building Floor Plans

NA	NA	NA
NA	NA	NA
NA	NA	NA
NA	NA	NA

20. **Special Fire Protection System for Protection of special Risks, if any:**

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

[Signature]
17/1/23

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

[Signature]
21/02/2023

CFO (D. P. Bhardwaj)

[Signature]
27/2/2023

CFO *[Signature]*
22/2/2023

Director *[Signature]*
23/2/23

Ajay Koley

FT letter is put up for kind perusal and
Signature please.

Director *[Signature]*
20/2/23
M

[Signature]
27/2/23