



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2023/ 132

Dated: 24/02/2023

FIRE SAFETY CERTIFICATE

Certified that the **Nav Bharti Public School located at Deepali, Pitampura, New Delhi- 110034**, is having two blocks. First Block (closed & not in School use) is comprised of ground floor only and Second Block comprised of Ground plus two upper floors was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/WZ/2019/552 dated 15.03.2019 (only for Second Block). The school building was re-inspected by the officer concerned of this department on 10.02.2023 in the presence of Sh. Sanjay Bhartiya, principal of the school and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with DoE circular 3298 - 3398 dated 01.03.2011 and that the premises/building is fit for occupancy class "Educational Building" Group B (**Ground plus Two Upper Floors Only**) with effect from 24/02/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 24/02/2023 at New Delhi by.

(Dharampal Bhardwaj)
Chief Fire Officer

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 54.
2. The Principal, Nav Bharti Public School, Deepali, Pitampura, New Delhi- 110034.

9c
24/2/23

INSPECTION REPORT

1. Name & address of the building : Nav Bharti Public School, Deepali, Pitampura, New Delhi- 34.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2019/552 dated 15.03.2019- for ground plus two upper floors only
5. Fire Safety directives letter No : DoE Circular No. 3298-3398 dated 01.03.2011
6. Date of inspection : 10.02.2023
7. Name of the Inspecting Officers : M.K. Chattopadhyay, DO (West)
8. Name and designation of officers from the building side : Ms. Sanjay Bhartiya, Principal
9. Year of Construction : 2000
10. Applicant's letter No. : nil dated 28.01.2023

The school complex is having two blocks, first block (ground floor only) is closed for school use and second block comprised of ground plus two upper floors was issued FSC by this department.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided (3.7 mts)	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	01	Provided (02)	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts	2x1.43 mts	MR, Old Case
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	Provided	MR
	g. Width of Corridor	1.5 mts	Provided (1.78 mts)	MR
	h. Door Size	1.0 mt.	Provided (1.10 mts)	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	NA	N/A	N/A
	• Upper floors	NA	N/A	N/A

Provision
Pres
Pres
Co
17
18

5	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC, CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	---	----	-----
	➤ Discharge of pump	360 & 180 LPM	Provided	MR, old case
	➤ Head of the pump	40 mts each	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 lts	Provided	MR
15	Exit Signage.	Required	Provided	MR

✗


Provision of Lifts.					
	MR	• Pressurization of Lift Shaft	N/A	N/A	N/A
	MR	• Pressurization of Lift lobby	N/A	N/A	N/A
	MR	• Communication In lift Car	N/A	N/A	N/A
		• Fireman's Grounding Switch	N/A	N/A	N/A
		• Lift Signage	N/A	N/A	N/A
	MR	17 Standby power supply	N/A	N/A	N/A
	MR	18 Refuge Area.			
	MR	➤ Total Area	N/A	N/A	N/A
		➤ Location	N/A	N/A	N/A
	N/	19 Fire Control Room			
	N/	• Detector System Panel	N/A	N/A	N/A
	N/	• Flow Switch Panel	N/A	N/A	N/A
	N/	• PA System Panel	N/A	N/A	N/A
	N/	• Batter backup	N/A	N/A	N/A
	N/	• Building Floor Plans	N/A	N/A	N/A
		20 Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the renewal of the NOC issued vide letter No. F6/DFS/MS/WZ/2019/552 dated 15.03.2019 (ground plus two upper floors only), is recommended.


Accordingly DFA is put up for approval & signature please.

D.O. (WEST) 2023
 DATED: 24/11/2023


 22/12/2023

Signature of the Inspecting Officer
Divisional Officer (West Division)


CFD (D.P.B)


 24/11/2023

~~Do of West~~

F.T. letter is put up for Sign. please

CFD (DPB)


 24/11/2023


 24/11

ms/ cas



Following fire safety directives must be adhered to: -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. This FSC is valid for the block comprised of ground, first & second floor only.
10. The school management has closed the block comprised of ground floor only for school use and if it is open or used for School purpose, this FSC will be null & void.