



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2023/NDZ/ 157

Dated: 02 / 03 / 2023

FIRE SAFETY CERTIFICATE

Certified that the **Prabhakar Model School (A-Block)**, located at **5th sloping, Near Masjid Wali Gali, Sonia Vihar, Delhi-110094**, building comprised of Ground & One upper floor (**Block-A & Block-B**) owned/occupied by Prabhakar Model School, was issued FSC vide letter No. F6/DFS/MS/School/2019/NDZ/1736 Dated 06/09/2019. The School building (Block-A) was re-inspected by the officer concerned of this department on 15/02/2023 in presence of Mr. B.S.Chauhan and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with D.O.E circular No. F16/Estate/CC/FS/2011/3298 to 3398 Dated 01/03/2011 and that the building (Block-A) is fit for occupancy class "**Educational**" (**Group-B**) with effect from 02 / 03 / 2023 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 02 / 03 / 2023 at New Delhi by.


(S.K. DUA)

**DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE.**

Copy to :-

1. The Manager, Prabhakar Model School, 5th sloping, Near Masjid Wali Gali, Sonia Vihar, Delhi-110094.
2. The Dy. Director of Education, B-Block Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate:

1. **NOC/FSC is valid for A-Block (Ground & First floor) only.**
2. **Management shall apply for Fire Safety Certificate of Block-B separately along with approved plans or as built plan through building authority.**
3. All the means of escape / entry / exit shall be kept free from any obstruction.
4. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
5. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
6. All the staff members must know the correct method of operation of fire fighting system.
7. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
8. **"The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".**

N/17

INSPECTION REPORT

1. Name & address of the building: M/s Prabhakar Model School,
5th slooping, Near Masjid Wali Gali,
Sonia Vihar, Delhi-110094.
2. Building is comprised of : Ground & One upper floor (A- Block)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2019/NDZ/1736 Dated 06/09/19
6. Fire Safety directives Letter No.: F16/Estate/CC/FS/2011/3298 to 3398 Dated: 01/03/2011
7. Date of inspection : 15/02/2023
8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.)
9. Name and designation of Officer
from the building side : Mr. B.S. Chouhan
10. Year of Construction : 2004
11. Applicant's letter No. : PMS/2023/01/10 Dated 12/01/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements Cir-01/03/11	Provided at Site	Remarks MR/NM
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	01	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 m	1.70 m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	1.50 mtr	1.50 mtr	MR
	f. Door Size	1.00 m	1.00 m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 nos.	04 nos.	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	MR

(Handwritten signature)

6.	First - Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A

Handwritten signature

16.	Provision of Lifts.			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- There are two separate block A & B. A Block is Ground & First Floor & B Block is now **Ground, First & Second Floor (Addition/Alteration)**. Earlier B-Block was G+1 upper floor. Fire Safety arrangement in B-Block is also not provided as per NBC Part-IV that is why FSC is recommended for A-Block only.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, The Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2019/NDZ/1736 Dated 06/09/19 as per D.O.E. Circular No. F16/Estate/CC/FS/2011/3298 to 3398 Dated 01/03/2011 renewal of FSC is recommended.

Ashok Kumar Jaiswal
17/02/2023

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East Division)

~~Dy. CFO (NDZ)~~

Corrected F.T. Pl.

1 wing
28/02/23

~~DO (ED)~~

corrected F.T. is placed for sign. pl.

~~Dy. CFO (NDZ)~~
F.P. wing

1 wing
01/03/23

1 wing
01/03/2023