

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2023/SZ/ 87

Dated: 06 / 03 / 2023

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the Name & Style of **M/s Smoke House Deli** located at **Shop No 252253, First Floor**, DLF Avenue Mall, District Center, Saket, Delhi 110017 in the building comprised of 03 Tire Basements, ground plus Seven upper floor owned/occupied by Unit of Impresario Entertainment and Hospitality Pvt Ltd) was issued Fire Safety Certificate by this department vide letter No F6/DFS/MS/EH/2020/SZ/56 dated 03/02/2020. The premise was re-inspected by the officer concerned of this department on 22/02/2023 in the presence of Mr. Avnish (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly, Group-D**" (**Restaurant at First floor only**) as above with effect from 06/03/2023 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06 / 03 / 2023 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
dg

Copy to: -

1. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016 (Ref. MHA Portal ID No 2023020101370 dated 01/02/2023)

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL /NBC Part- IV.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/16



**INSPECTION REPORT**

1	Name & Address of the Building	M/s Smoke House Deli (Unit of Impresario Entertainment and Hospitality Pvt Ltd) located at Shop No 252253, First Floor, DLF Avenue Mall, District Center, Saket, Delhi 110017		
2	Type of Occupancy	Group-D Assembly Building. (Restaurant is running at First Floor only)		
3	Building Comprised of	03 tier Basements, Ground + 07 Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2020/SZ/56 dated 03/02/2020		
6	Fire Safety Directives Letter No	DLF Place Mall- F.6/MS/DFS/BP/2005/2073 dated 04/10/2005 & F.6/MS/DFS/BP/2019/135 dated 01/04/2019		
7	Date of Inspection	22/02/2023		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Avnish (Manager)		
10	Year of construction	1996		
11	Applicant letter No.	MHA Portal ID No 2023020101370 dated 01/02/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement/ Existing Fire Protection	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>	( DLF Place Mall - F.6/DFS/MS/2022/Mall/SZ/266 Dt. 15/06/2022)		
	• Road width	12 m	Provided by Mall	MR
	• Gate width	7m	N/A	N/A
	• Width of internal road	6m	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	a) Number of Staircase	Provided & Maintained by DLF Avenue Mall		
	➤ Upper floors.	02 Nos	GF to FF-16 FF to 2 <sup>nd</sup> F- 14 nos GF to T- 06 Nos	MR
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase	Provided & Maintained by DLF Avenue Mall		
	➤ Upper floors	1.50 mtr & 2m	1.50 mtr & 2m	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits	Provided & Maintained by DLF Avenue Mall		
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	2m	6.34m & 0.89 m	MR
3	<b>Compartmentation.</b>	Provided & Maintained by DLF Avenue Mall		
	• Fire check door.	Restt within Mall	Provided *	MR
	• Sealing of electrical shafts.	Restt within Mall	Provided *	MR
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	<b>Smoke Management system.</b>	Provided & Maintained by DLF Avenue Mall		
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fans Provided	MR
5	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	08 Nos	MR
	• Types	ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI Marking	Required	Provided	MR
6	<b>First Aid Hose Reels.</b>	Provided & Maintained by DLF Avenue Mall		
	• Total numbers on each floor.	One near Restt	Provided *	MR
	• Length of hose-reel hose.	30m	Provided *	MR
	• Nozzle Diameter	5mm	Provided *	MR
7	<b>Automatic fire detection &amp; alarming system.</b>	(Provided & Maintained by DLF Avenue Mall		
	• Type of detectors	Required	Provided *	MR
	• Location of Main Panel	Required	Provided *	MR

*(Handwritten signatures)*



2/17

	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	Required	Provided *	MR
		Required	Provided *	MR
		Required	Provided *	MR
8	<b>MOEFA</b>	Required	Provided *	MR
9	<b>Public Address System</b>	N/A	Provided *	MR
10	<b>Automatic Sprinkler System</b>	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground floor.</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided *	MR
		Required	Provided *	MR
		N/A	N/A	N/A
11	<b>Internal Hydrants.</b>	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	Required	Provided *	MR
		One near Restt	Provided *	MR
		One near Restt	Provided *	MR
12	<b>Yard Hydrants.</b>	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	N/A	Provided *	N/A
		N/A	Provided *	N/A
13	<b>Pumping arrangements.</b>	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting/Manual Stopping.</li> <li>Pump house access.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul>	<b>Common pumping arrangements for entire bldg</b>		
		4500 LPM	Provided *	MR
		70m	Provided *	MR
		02 Nos.	Provided *	MR
		180 LPM	Provided *	MR
		70m	Provided *	MR
		4500 LPM	Provided *	MR
		70m	Provided *	MR
		Required	Provided *	MR
		Required	Provided *	MR
		450 LPM	Provided *	MR
		40 m	Provided *	MR
		Required	Provided *	MR
		Required	Provided *	MR
14	<b>Captive water storage for fire fighting.</b>	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> <li>Underground tank capacity.           <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	Required	3,70,000 Ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	30,000 Ltrs	MR
		Required	Provided	MR
15	<b>Exit Signage.</b>	Provided & Maintained by DLF Avenue Mall		
16	<b>Provision of Lifts.</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	<b>Standby Power Supply</b>	N/A	N/A	N/A
18	<b>Refuge Area</b>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	<b>Fire Control Room.</b>	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> <li>Detector system panel.</li> <li>Flow switch panel.</li> <li>PA system panel.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

N/18



	<ul style="list-style-type: none"> <li>Battery backup.</li> <li>Building floor plan.</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

Note: \* Provided & Maintenance by the DLF Avenue Mall, Saket, New Delhi

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2020/SZ/56 dated 03/02/2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Handwritten signature*

*Handwritten signature and date: 2/3/2023*

Signature of the Inspection Officer  
Name: Sh. Manoj Kumar Sharma  
Design: DO (South)

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

CFO (HQ)

*Handwritten signature and date: 3/3/2023*

~~Director~~  
~~Asst. Secy - online~~  
~~Asst. Secy~~

As approved, F.T. letter is prepared & put up for kind perusal, approval/signature

Dist DFS  
*Handwritten signature*

*Handwritten signature and date: 6/3/23*

*Handwritten text: MSB*

*Handwritten text: uploaded 6/3/23*