

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2023/ 127

Dated : 02.03.2023

FIRE SAFETY CERTIFICATE

Certified that the **Girls Hostel YWCA** located at **Ashoka Road, New Delhi** comprised of **Basement + Ground + 03 Upper floors** was earlier granted FSC by this department vide letter No.F6/DFS/MS/NDZ/2020/133 dated **05/02/2020**. Now, the premises was inspected by the officer concerned of this department on **23/02/23** in the presence of **Mr. Gabril** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, (Sub Division-A-1)** with effect from **02/03/2023**..... for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued **02/03/2023** at New Delhi by.

(Signature)
 01/03/23
 (S.K. Dua)

Dy. Chief Fire Officer
 Delhi Fire Service

Copy to:-

1. The Chief Architect , NDMC , Plalika Kendra ,New Delhi
2. Mrs. Nirmala Prabhakaran, **President**, Girls Hostel YWCA located at Ashoka Road, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

123
INSPECTION REPORT

1. Name & address of the building: Girls Hostel YWCA located at Ashoka Road, New Delhi.
2. Type of occupancy:- Residential Building
B + Ground + 03 Upper floors
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/NDZ/2020/133 dated 05/02/2020.
5. Fire safety directives No.- N/A
6. Date of inspection:- 23/02/23
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD) & Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer From the building side:- Mr. Gabriel
9. Year of construction:- 1995
10. Applicant's letter No:- No. Y/CHWW/2022-23/004 dated 31/01/2023.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1. Access to Building				
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	05 mtr.	05 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2. Number, Width Type & Arrangement of Exits				
A. Number of staircases				
	1. Upper floors	03 Nos.	03 Nos.	MR
	2. Basements	02 Nos.	02 Nos.	MR
B. Width of staircase				
	1. Upper floors	1.25 mtr.	1.25 mtr. each	MR
	2. Basements	1.25 mtr.	1.25 mtr. each	MR
C. Protection of exits				
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	01 mtr.	MR
3. Compartmentation				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4. Smoke Management System				
	1) Basements	12 ACPH	Exhaust Fan	MR
	2) Upper floors	12 a/c per hour	Natural	MR

N/2M

5.	Fire Extinguishers			
	1) Total numbers	18 Nos.	18 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02 /	02	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm /	MR
	2) Number of hydrants per floor	02	02 ✓	MR
	3) Hose box	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	04	04	MR
	2) Hose box	04	04	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900 & 900 LPM	900 & 900 LPM /	MR
	b) Head of pump	40 mtr.	40 mtr. /	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR

14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00,000 ltr.	1,00,000 ltr. ✓	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 ltr.	20,000 ltr. ✓	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC, CO2			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/NDZ/2020/133 dated 05/02/2020, under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Rajinder Atwal
28/2/23

Name :- Rajinder Atwal
Designation :- DO (CD)

Signature of the Inspecting Officer

Ravinder Sighn
28/2/23

Name :- Ravinder Sighn
Designation :- ADO (CC)

Dy. CPO (MD2)

F.T. please.

Rajinder Atwal
21/03/23

ADO (CC) As recommended by fire department for fire
prevention and separation please.

Dy. CPO (MD2)

Rajinder Atwal
21/03/23
F.T. please

Rajinder Atwal
21/03/23