

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2023/Hospital/WZ/ 126

Dated: 02/03/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Jaipur Golden Hospital, Sector - 03, Rohini, Delhi-110085**, comprised of **Block A-B+G+1, Block- B&C-B+G+3, Block-D-B+G+5** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/Hospital/2020/WZ/192 Dated 29.04.2020**. The premises was re-inspected by the officer concerned of this department on **06.02.2023** in the presence of **Mr. Manoj Malik (Fire Officer)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy **Class "C"** with effect from 02/03/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/03/2023 at New Delhi by

  
(Atul Garg)  
**DIRECTOR**  
Ph; 011-23414000  
etc  
GJ

Copy to :-

1. The Director, Jaipur Golden Hospital, Sector - 03, Rohini, Delhi-110085.

**Conditions for the validity of fire safety certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_tire/FIRE/Home/Fire+Safety+Acts+and+Rules](http://www.delhi.gov.in/wps/wcm/connect/doi_tire/FIRE/Home/Fire+Safety+Acts+and+Rules)

/ [http://www.delhi.gov.in/wps/wcm/connect/doi\\_tire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_tire/FIRE/Home/Forms)

## SURPRISE INSPECTION REPORT

**Block A-B+G+1, Block- B&C-B+G+3, Block-D-B+G+5**

1. Name & address of the building : Jaipur Golden Hospital, Sector - 03, Rohini, Delhi-110085
2. Type of Occupancy : **Hospital (Class "C")**
3. Composition of building : Block A-B+G+1, Block- B&C-B+G+3, Block-D-B+G+5
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/Hospital/2020/WZ/192 Dated 29.04.2020.
6. Fire Safety directives letter No : N/A
7. Date of inspection : 06.02.2023
8. Name of Inspecting Officer : A. K. Sharma ADO (Rohini) & D.B Mukherjee, DO (NW)
9. Name and designation of officers  
From the building side : Mr. Manoj Malik (Fire Officer)
10. Year of Construction : 1990 & 1999
11. Application's letter No. : JGH/ADMIN/FIRE/2022/968 dated 19.12.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	09 mtr 05 mtr 06 mtr	09 mtr Provided 06 mtr	M/R M/R M/R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	d. Number of staircases	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	07 07	07 07	MR M/R
	e. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	2 mtr X 3 & 4 SC 1 mtr 2 mtr X 3 & 04 SC 1 mtr	03 SC 2 mtr & 04 SC 1 mtr 03 SC 2 mtr & 04 SC 1 mtr	M/R M/R
	f. Protection of exits			
	Fire check door	Required	Required	M/R
	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	NA	Provided	NA
	d. No. of continuous staircases to terrace	03	07	M/R
	e. Width of Corridor			
	f. Door Size	2 mtr	2 mtr	M/R
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required Required Required NA NA	Provided Provided Provided NA NA	M/R M/R M/R NA NA
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Provided GF Provided GF	M/R M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	Water CO2 09 ltr CO2 type 4.5 KG DCP Type ISI Marked	188 Yes Yes	M/R M/R M/R
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	5 Nos. 30 m 5 mm	Provided Provided Provided	M/R M/R M/R

10/23

N/68

Special Fire Protection

7.	<b>Automatic fire detection and alarming system</b>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Common Area	Provided	M/R
			Provided	M/R
8.	<b>MOEFA</b>	Required	Provided	M/R
9.	<b>Public Address System</b>	Required	Provided	M/R
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground &amp; Upper Floors</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	M/R
		Required	Provided	M/R
		NA	NA	NA
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm	Provided	M/R
		05 Nos.	Provided	M/R
		05 Nos.	Provided	M/R
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	Required	Provided	M/R
		Required	Provided	M/R
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> <li>Pump House Access</li> </ul>	2400 LPM	Provided	M/R
		70 M	Provided	M/R
		2 electric 1 stand by 0 Jockey	Provided	M/R
		180 LPM	Provided	M/R
		70 M	Provided	M/R
		2400 LPM	Provided	M/R
		70 M	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	3,00,000 lts	3,00,000 lts	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		20,000 ltr	20,000 ltr	M/R
15.	<b>Exit Signage.</b>	Required	Provided	M/R
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	Required	Provided GF	M/R
		NA	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
17.	<b>Standby power supply</b>	Required	Provided	M/R
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	Required	Provided	M/R
		4 <sup>th</sup> Floor	Provided	M/R
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> </ul>	Required	Provided	M/R
		Required	Provided	M/R

*[Handwritten signature]*

N/69

20. Special Fire Protection System for Protection of special Risks, if any:	PA System Panel	Required	Provided	M/R
	Battery backup	Required	Provided	M/R
	Building Floor Plans	Required	Provided	M/R
			No Special Risk at Present	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F.6/DFS/MS/Hospital/2020/WZ/192** Dated **29.04.2020** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*[Signature]*  
 02/02/2023  
 Signature of the Inspecting Office  
 Name: - D.B Mukherjee  
 Designation:- DO/NW

*[Signature]*  
 7/1/23  
 Signature of the Inspecting Officer  
 Name: - A.K.Sharma  
 Designation:- ADO/Rohini

*[Signature]*  
 14/2/2023

*[Signature]*  
 14/2/2023

*[Signature]*  
 15/2/2023

*[Signature]*  
 15/2/2023

FT letter is put up for kind perusal and signature please.

*[Signature]*  
 11/3/23

*[Signature]*  
 2/03/23  
 Director