

r.n

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No. F6./DFS/MS/2023/Banquet/WZ/ 114

Dated: 27/02/2023

FIRE SAFETY CERTIFICATE

Certified that the **Laxmi Radhey Shyam Charitable Club, Community Hall, (Grand Utsav Bhawan)** located at **Pkt-B-10, Sector-3, Delhi-85**, comprised of **Basement + Ground + 02 upper floors** owned/ occupied by **Grnad Utsav Bhawan (A unit of Laxmi Radhey Shyam Charitable Club)** has already been issued FSC by this department vide letter No **F.6/DFS/MS/2019/WZ/347 dated 08.02.2019**. The premises was re-inspected by the officer concerned of this department on **09.02.2023** in the presence of **Mr. Ankush** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "**Assembly Group D-5**" with effect from 27/02/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/02/2023 at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

N/27

INSPECTION REPORT

1. Name & address of the building : Laxmi Radhey Shyam Charitable Club, Community Hall, (Grand Utsav Bhawan) located at Pkt-B-10, Sector-3, Delhi-85
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (B + Gr. + 02 upper floors) Basement -Storage, Gr. & 1st floor-Banquet, 2nd floor -7 Bridal rooms
4. Details of Previous NOC : F.6/DFS/MS/2019/WZ/347 dated 08.02.2019.
5. Fire Safety directives letter No : F.6/DFS/MS/2011/548 dated 25.03.2011.
6. Date of inspection : 09.02.2023
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mr. Ankush
9. Year of Construction : 2009
10. Applicant's letter No. : Online e-mail dated 04.02.2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Accessible 4m NA 	<ul style="list-style-type: none"> MR MR(Old case) NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<ul style="list-style-type: none"> 02 02 	<ul style="list-style-type: none"> 02 02 	<ul style="list-style-type: none"> MR MR
	e. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<ul style="list-style-type: none"> 1.5m 1.5m 	<ul style="list-style-type: none"> 1.50 & 1.45m 1.50m & 1.45m 	<ul style="list-style-type: none"> MR(Old case) MR(Old case)
	f. Protection of exits			
	Fire check door	Required in Basement	Provided	MR
	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.5m x 2	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> Required Required Required NA NA 	<ul style="list-style-type: none"> Provided in basement Provided Provided NA NA 	<ul style="list-style-type: none"> MR MR MR NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> 30 a/c per hour 12 a/c per hour 	<ul style="list-style-type: none"> Exhaust fan Natural ventilated 	<ul style="list-style-type: none"> MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 10nos. ABC/CO2 ISI marked 	<ul style="list-style-type: none"> 12nos. ABC-12nos. Yes 	<ul style="list-style-type: none"> MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<ul style="list-style-type: none"> 01 30mm 5m 	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR
7.	Automatic fire detection and alarming system			

(Signature)

N/28

19. Fire Cont. Loc

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Provided	MR
		GF	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	2280lpm	2280lpm	MR
		60m	60m	MR
		01nos.	01nos.	MR
		180lpm	180lpm	MR
		60m	60m	MR
		2280lpm	2280lpm	MR
		60m	60m	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450lpm	450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	50,000ltr	50,000ltr	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		5,000ltr	5,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided DG set	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area 	NA	NA	NA

Handwritten signature/initials

11/29

Location		NA	NA	NA
20.	Fire Control Room	NA	NA	NA
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 188 dated 01.02.2023, the FSC issued vide letter no. **F.6/DFS/MS/2019/WZ/347** dated **08.02.2019**, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

~~ADO Rohini~~

FT letter is put up for kind perusal and signature please.

~~ADO Rohini~~

Please upload on MHA portal after dispatch on CAE D 2022/12020450

Ms Cell

Uploaded
28/2/23