

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/Mixed/2023/SZ/ 139

Dated: 13/03/2023

FIRE SAFETY CERTIFICATE

Certified that the **Sanskrit Bhawan**, located at A-10, Qutab Institutional Area, Aruna Asaf Ali Marg, New Delhi 110067 comprised of Basements, Ground plus Three Upper Floors, owned/occupied by All India Sanskriti Sahitya Sammelan was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MSSZ/2016/144 dated 20/01/2016. The premise was re-inspected by the officer concerned of this department on 02/03/2023 in the presence of Sh. Devender Pratap Singh and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Mixed Occupancy (**Business & Educational**) with effect from 13/03/2023 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 13/03/2023 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. For All India Sanskriti Sahitya Sammelan, "Sanskrit Bhawan", located at A-10, Qutab Institutional Area, Aruna Asaf Ali Marg, New Delhi 110067

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. The basement shall be used as per the provisions of BBL /NBC Part- IV
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/19



INSPECTION REPORT

1	Name & Address of the Building	All India Sanskriti Sahitya Sammelan, Sanskrit Bhawan, A-10, Qutab Institutional Area, Aruna Asaf Ali Marg, New Delhi 110067		
2	Type of Occupancy	Education & Business, "Mixed occupancy"		
3	Building Comprised of	Basements, Ground + 03 Upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MSSZ/2016/144 dated 20/01/2016		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/98/855 Dated 30/04/1998		
7	Date of Inspection	02-03-2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Devender Pratap Singh (Maintains)		
10	Year of construction	2000		
11	Applicant letter No.	Outdoor diary no 10631 dated 31/01/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	30 mtr	MR
	• Gate width	Required	3.5 mtr each	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	02 Nos	Provided & 01 ramp	MR
	b) Width of Staircase			
	➤ Upper floors	1.25 m	1.40m & 1.26m	MR
	➤ Basement floor	1.25m	1.50m, 1.35m & 2.04m ramp	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	02 Nos	Provided	MR
	e) Width of corridor	1.5 mtr	1.5 mtr	MR
	f) Door size	1m	1m	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	Provided	MR
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	15 nos.	Provided	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	01 Nos	Provided 01 at each	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mm	5mm	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8	MOEFA	Required	Provided	MR

N/20

75
 011 013
 019 017

9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper floors (except EE area) 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Number of Hydrant per floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	Required	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	Required	Provided	MR
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Head of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of main pumps. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Auto Starting/Manual Stopping. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump house access. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. 	900 LPM	Provided	MR
	<ul style="list-style-type: none"> Head of pump. 	56m	Provided	MR
	<ul style="list-style-type: none"> Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump. 	Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	50,000 ltrs	Provided	MR
	<ul style="list-style-type: none"> Draw-off connection. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire Service Inlet. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Access to tank. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity. 	12,500 Lts	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's switch. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift signage. 	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Flow switch panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> PA system panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Battery backup. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Building floor plan. 	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	NA	NA	NA

N

O

M

N/3A

Sanskrit Bhawan, A-10, Qutab Institutional Area, Aruna Asaf Ali Marg, New Delhi 110067

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 2262 dated 06/09/2022.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MSSZ/2016/144 dated 20/01/2016, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

[Handwritten Signature]

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

[Handwritten Signature]
413

[Handwritten Signature]
6/31/2023

[Handwritten Signature]
Director

FFPLs

[Handwritten Signature]
ADP/BCP

As approved, F.I. letter is put up for your signature pl

[Handwritten Signature]
9/3/2023

[Handwritten Signature]
Director

[Handwritten Signature]