

C-26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2023 / School / WZ / 168

Dated: 10/03/2023

FIRE SAFETY CERTIFICATE

Certified that **Silver Belt Public School** located at **Village Palla, Delhi-110036** comprised of **Ground+One upper floor only** owned/occupied by **Silver Belt Public School** was issued fire safety certificate **vide letter no. F-6/DFS/MS/School/2019/2365 dated-24/02/2019**. The premises was inspected by the officer concerned of this department on dated 28.02.2023 in the presence of Sh. Jagdish Kumar (Manager) and found that the fire prevention & fire safety arrangements provided in the building found in good working condition. The premises have therefore deemed complied with the requirements of **Circular No. 262-362 dated 17/01/2005** issued by Director of Education and that the building / premises is fit for occupancy of **Class B (Educational)** with effect from 10/03/2023 for a period of **three years**, subject to the compliance of the conditions mentioned below.

Issued on 10/03/2023..... at New Delhi


(Atul Garg)
Director
Delhi Fire Service


Copy to : -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Silver Belt Public School, Village Palla, Delhi-110036.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Silver Belt Public School located at Village Palla, Delhi-110036.
 2. Type of Occupancy : Educational
 3. Building Comprised : Ground + First Floor
 4. Type of Case : Renewal
 5. Details of Previous NOC : Letter No. F.6/DFS/MS/School/2019/2365 Dated-24/12/2019
 6. Fire Safety directives letter No : Dir of Edu. Cir dated 17/01/2005
 7. Date of inspection : 28/02/2023
 8. Name of Inspecting Officer : ADO, R.K.Sinha
 9. Name and designation of officers
 From the building side : Sh. Jagdish Kumar (Manager)
 10. Year of Construction : 2000
 11. Applicant's letter No. : SBPS/02/2023 , Dated-08/02/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases	1.50 m	1.05 m & 0.95 m	MR(old case)
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	1.00 m with door fitting	MR(old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA

Handwritten signature/initials

	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural Ventilated	MR
5.	Fire Extinguishers	05	Provided	MR
	<ul style="list-style-type: none"> Total numbers Types IS marking 	ABC	ABC	MR
		Yes	Yes	MR
6.	First-Aid Hose Reels	01	Provided	MR
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

n n

2/19

MR	➤ Pump House Access	NA	NA	NA
	• Terrace level	-	-	-
MR	➤ Discharge of pump	220 lpm	Provided	MR
MR	➤ Head of the pump	40 m	Provided	MR
MR	➤ Power Supply	NA	NA	NA
		-	-	-
MR	➤ Auto Starting of pump	NA	NA	NA
MR	MR			
MR	MR			
MR	MR			
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2500 ltrs	2500 ltrs	MR
		NA	NA	NA
15.	Exit Signage.			
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Handwritten signatures and initials in blue ink.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 262-362 dated 17.01.2005 it is recommended to renew the Fire Safety Certificate issued vide letter no.F-6/DFS/MS/School/2019/2365.

~~DO (P/S)~~

~~Kumar
05/03/2023~~

~~CFO (D.P. Bhardwaj)~~

~~[Signature]
01/03/2023~~

~~CFO
[Signature]
06/03/2023~~

~~Director
[Signature]
01/03/23~~

~~Any an Sir, H. J. Mittani (In-charge of supplies)~~

~~[Signature]
ADO (B/W)
09/03/23~~

~~Director (P/S)
[Signature]
01/03/23
me~~

~~[Signature]
ADO (B/W)
09/03/23~~
Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.