



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज का दिन
आशा भरोसा

No. F6/DFS/MS/EH/SZ/2023 / 93

Dated: 07/03/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Soul (Restaurant & Discotheque), a unit of Striker Beverages Pvt. Ltd. located at Hotel 'The Ashok' at 50- B, Diplomatic Enclave, Chanakyapuri, New Delhi-110021, is running at ground floor of the Hotel building comprised of Ground + 07 upper floors. had been issued FSC vide letter no. F.6/DFS/MS/EH/2020/SZ/159 dated 18.03.2020. The said Restaurant was inspected by a team of officers from this department on 06.03.2023 in presence of Mr. Manish (partner) and it was found to have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class Group 'D' (Assembly – Restaurant + discotheque) with effect from 07/03/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 07/03/2023 at New Delhi by

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi.
2. The Soul (Restaurant & Discotheque), a unit of Striker Beverages Pvt. Ltd. located at Hotel 'The Ashok' at 50- B, Diplomatic Enclave, Chanakyapuri, New Delhi-110021.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Basement shall be used as per NBC/UBBL.
9. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

~17
INSPECTION REPORT

1.	Name and address of the building:	M/s Soul (Restaurant & Discotheque), a unit of Striker Beverages Pvt. Ltd. located at Hotel 'The Ashok' at 50- B, Diplomatic Enclave, Chanakyapuri, New Delhi-110021.
2.	Building is comprised of	Ground + 7 upper floors Said restaurant is running only at ground floor of the building
3.	Type of occupancy	Assembly – Restaurant cum Discotheque.
4.	Type of case:	Renewal
5.	Details of previous FSC:	F6/DFS/MS/EH/2020/SZ/159 dated 18.03.2020
6.	Fire safety directives no.:	NBC Part IV/UBBL- 2016
7.	Date of inspection:	06.03.2023
8.	Name of the inspecting officer:	Manoj Kumar Sharma, DO (SD) Rajesh Kumar Shukla, ADO (M. Road)
9.	Name and designation of the officer from the building side:	Mr. Manish (Partner)
10.	Year of construction:	Of parent building 1956.
11.	Reference letter no.:	Online ID no.20230210011796 dated 13.02.2023

S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements as per 35(6)	Provide at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	Required	15 mtrs.	MR
	B Gate width	Required	06 mtrs	MR
	C Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits:			
	A No. of Staircase:	Restaurant at ground floor only		
	a) Upper floor	NA	NA	NA
	b) Basements	NA	NA	NA
	B Width of the Staircase:			
	a) Upper floors			
	i) Main staircase	NA	NA	NA
	ii) Atl. staircase	NA	NA	NA
	b) Basements	NA	NA	NA
	C Protection of Exits			
	a) fire check door	NA	NA	NA
	b) pressurization	NA	NA	NA
	D No. of continuous staircase to terrace	NA	NA	NA
	E Width of the corridor	NA	NA	NA
	F Door size	2 mtrs/1.5 mtrs (exits)	Provided	MR
3	Compartmentation:			
	A Fire check doors	NA	NA	NA
	B Sealing of horizontal & vertical opening	NA	NA	NA
	C Fire rating of shaft doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA (seperate ventilation system for restaurant)	NA	NA
4	Smoke Management System:			
	A Basements	NA	NA	NA
	B Upper floors/Restaurant area	12 ACPH	Provided	MR
5	Fire Extinguishers:			
	A Total numbers	04 nos.	06 nos.	MR
	B Types	ABC + CO ₂	ABC + CO ₂	MR
	C ISI marking	ISI marked	ISI marked	MR

L

m

Dt

6	First Aid Hose reel:	Water based Fire Fighting system common for the entire building		
	A Total no. at each floor	02 nos.	02 nos.	MR
	B Length of hose reel	30 m	30 m	MR
	C Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS):			
	A Type of detectors	Smoke and Heat	Provided	MR
	B Location of main panel	Required	Provided near staff toilet at ground floor	MR
	C Location of repeater panel	NA	NA	NA
	D Alternate power source	Required	Provided	MR
	E Hooter's location			
8	MOEFA:	Required	Provided	MR
9	Public Address System:	Required	Provided	MR
10	Automatic Sprinkler System:			
	A Basement	NA	NA	NA
	B Upper floor	Required	Provided	MR
	C Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants: Provided & maintained by building management			
	A Size of wet riser/ down comer	100 mm	Provided	MR
	B No. of hydrants per floor	1 no.	1 no. near restaurant	MR
	C Hose box	1 no.	1 no.	MR
12	Yard Hydrants:			
	A Total no. of hydrants	NA	NA	NA
	B Hose box	NA	NA	NA
13	Pumping Arrangements: Common for entire building			
	A Ground Level			
	a) Discharge & head of main pump	2850 lpm/80 mtrs	Provided	MR
	b) Number of main pump	02 nos.	Provided	MR
	c) Discharge & head of jockey pump	225 lpm/80 mtrs	Provided	MR
	d) Discharge & head of standby pump	2850 lpm/80 mtrs	Provided	MR
	e) Auto starting/ manual stopping	Required	Provided	MR
	B Terrace Level (Common for entire building)			
	a) Discharge of terrace pump	900 lpm	900 lpm	MR
	b) Head of terrace pump	40 m	40 m	MR
	c) Alternate power supply	Required	Provided	MR
	d) Auto starting of pump	Auto	Provided	MR
14	Captive Water Storage for Fire Fighting: (Common for entire building)			
	A Underground tank capacity	4,00,000 ltrs.	Provided	MR
	B Draw off connection	Required	Provided	MR
	C Fire service inlet	Required	Provided	MR
	E Access to tank	Required	Provided	MR
	D Overhead tank capacity	25,000 Liters	Provided	MR
15	Exit Signage:	Required	Provided	MR
16	Provision of lift:			
	A Pressurization of lift shaft	NA	NA	NA
	B Pressurization of lift lobby	NA	NA	NA
	C Communication in lift car	NA	NA	NA
	D Fireman switch	NA	NA	NA
	E Lift signage	NA	NA	NA
17	Standby Power Supply:	Required	Provided	MR

(Handwritten signatures)

18 Refuge Area:				
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19 Fire Control Room:				
A	Fire detection system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P a system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20 Special Fire Protection for special risk if any				
A	Special Fire Protection system for Protection of Special Risk, if any:			NA

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Not Provided (NP) Provided Not Functional (PNF).

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 35 of Delhi Fire Service Rules 2010.

Manoj
 Signature of the Inspecting Officer
 Name: Manoj Kumar Sharma
 Designation: DO(SD)

Rajesh
 06/13/23
 Signature of the Inspecting Officer
 Name: Rajesh Kumar Shukla
 Designation: ADO (M. Road)

CFO
[Signature]
 7/31/2023

~~Director~~
[Signature]
 7/09/23

FF 99

ADO/F/M/ML

Sir, as approved F.T. letter is put up for signature please

w/director
[Signature]
 7/09/23

[Signature]
 07/13/2023

Uploaded
 07/13/23
[Signature]