

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001



No.F.6 DFS/MS/School/2023/SZ/ 170

Dated: 10/03/2023

FIRE SAFETY CERTIFICATE

Certified that the **Master Mind Public School** located at Khasra No 178, Neb Sarai, IGNOU Road, New Delhi 110003 comprised of Ground plus Two upper floors (2nd Floor Closed with Brick Wall by the school management) School running at Ground and First Floor only owned/ occupied by Master Mind Public School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2006/2285 Dated 01-09-2006 for GF only. The said premise was re-inspected by officer concerned of this department on 01/02/2023 in presence of Mrs. Rajesh Shoken (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate e/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 10/03/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 10/03/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE


Copy to: -

1. The Principal, Master Mind Public School located at Khasra No 178, Neb Sarai, IGNOU Road, New Delhi 110003
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Master Mind Public School, Khasra No 178, Neb Sarai, IGNOU Road, New Delhi 110003		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground plus Two Upper floor But Second floor closed by management, School running at Ground and First Floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2006/2285 Dated 01-09-2006 for GF only		
6	Fire Safety Directives Letter No	DOE Circular dated 17/01/2005		
7	Date of Inspection	02/03/2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Rajesh Shoken (Principal)		
10	Year of construction	2002 - 2008		
11	Applicant letter No.	M/M/P/S-648 dated 20/02/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	Required	5.21 mtr	MR
	• Gate width	Required	Approachable from road	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	01 Nos	02 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr	1.20 mtr & 0.75 mtr	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	-NA-	-NA-	-NA-
3.	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	Required	11 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	-NA-	-NA-	-NA-
	• Length of hose-reel hose.	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-
7.	Automatic fire detection & alarming system.			



 M


NA
 NA
 NA
 NA
 NA
 NA
 NA

• Flow switch panel	-NA-	-NA-	-NA-
• PA system panel	-NA-	-NA-	-NA-
• Battery backup	-NA-	-NA-	-NA-
• Building floor plan	-NA-	-NA-	-NA-
20. Special Fire Protection System for the Protection of special Risk, if any.			-NA-

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection. As per the school management request letter dated 20/02/2023, school comprised of Ground plus two upper floor (2nd floor closed with brick wall photo enclosed at C-19 & C-20) and School running at ground and first floor only.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No F6/DFS/MS/2006/2285 Dated 01-09-2006 for GF only, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Design: ADO (BCP)

DO (SD)

msk
4/3

eps
 6/21/2023

Director
 4/13/23

ADP

As approved, F-1 letter is put up for
 your signature A

Director
 4/13/23
m

ADP
 9/3/2023