

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2023/SZ/ 90

Dated. 07/03/2023

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name and style of M/s **Shalom Unwind LBC** located at N-17, **First & Second Floor**, N Block Market, Greater Kailash-I, New Delhi-110048 in the building comprised of Ground plus Three Upper floors owned/occupied by A unit of Amani Global Pvt. Ltd was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/EH/2020/SZ/115 dated 04/08/2020. The restaurant premise was re-inspected by the officer concerned of this department on 01/03/2023 in the presence of Mr. Dhiraj Arora and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building" (Restaurant at First & Second Floor only)** as above with effect from 07/03/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/03/2023 at New Delhi by

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi-110016 (Ref. MHA Portal ID 2023022202453 dated 22/02/2023)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL /NBC Part- IV.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."


INSPECTION REPORT

Name & Address of the Building	M/s Shalom Unwind LBC (A unit of Amani Global Pvt. Ltd.) located at N-17, First & Second Floor, N Block Market, Greater Kailash-I, New Delhi-110048.			
2 Type of Occupancy	Group-D "Assembly Building" (Restaurant)			
3 Building Comprised of	Basement, Ground + 03 upper floors (Restaurant running at 1st & 2nd floor of the building)			
4 Type of Case	Renewal			
5 Details of Previous NOC	F.6/DFS/MS/EH/2020/SZ/115 dated 04/08/2020			
6 Fire Safety Directives Letter No	Nil			
7 Date of Inspection	01/03/2023			
8 Name of the Inspecting Officers	DO (South) & ADO (BCP)			
9 Name & Designation of Officers from the building side	Mr. Dhiraj Arora			
10 Year of construction	1996			
11 Applicant letter No.	MHA Portal ID 2023022202453 dated 22/02/2023			
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks NR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required	6 mtr	MR
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Two	Two	MR ✓
	➤ Basement floor.	-N/A-	-N/A-	-N/A-
	b) Width of Staircase			
	➤ Upper floors	Required	1.50m & 1.25m	MR ✓
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	Required	One	MR
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	2 m	2 m & 1.25m	MR
3	Compartmentation.			
	• Fire check door.	-N/A-	-N/A-	-N/A-
	• Sealing of electrical shafts.	-N/A-	-N/A-	-N/A-
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	-N/A-	-N/A-	-N/A-
4.	Smoke Management system.			
	• Basement	-N/A-	-N/A-	-N/A-
	• Upper floors	Required	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	• Total numbers	10 nos.	10 nos.	MR
	• Types	ABC / Co ₂ / W.Co ₂	ABC & Co ₂	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	One	One at alternate floor	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

R D

N/19

7 Automatic Fire Detection & Alarming System.				
	• Type of Detectors	-N/A-	-N/A-	-N/A-
	• Location of Main Panel	-N/A-	-N/A-	-N/A-
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	-N/A-	-N/A-	-N/A-
	• Hooter's location	-N/A-	-N/A-	-N/A-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-N/A-	-N/A-	-N/A-
10. Automatic Sprinkler System				
	• Basement.	-N/A-	-N/A-	-N/A-
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11. Internal Hydrants.				
	• Size of Riser / Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	Required	One at alternate floor	MR
	• Hose box.	Required	One at alternate floor	MR
12. Yard Hydrants.				
	• Total number of hydrants.	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
13 Pumping arrangements				
	• Ground Level			
	➤ Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40 mtrs	40 mtrs	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14. Captive water storage for firefighting.				
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	10,000 Ltrs	10,000 Ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16. Provision of Lifts.				
	• Pressurization of lift shaft.	-N/A-	-N/A-	-N/A-
	• Pressurization of lift lobby.	-N/A-	-N/A-	-N/A-
	• Communication in lift car.	-N/A-	-N/A-	-N/A-
	• Fireman's switch.	-N/A-	-N/A-	-N/A-
	• Lift signage.	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	Required	Provided	MR
18. Refuge Area				
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-



19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any:	-N/A-	-N/A-	-N/A-

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection and 3rd floor regularized plan approved by MCD vide dated 28/12/2021 enclosed at C/50.

In view of deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of the FSC issued vide letter no. F.6/DFS/MS/EH/2020/SZ/115 dated 04/08/2020 under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

manu
 Signature of the Inspection Officer
 Name: Sh. Manoj Kumar Sharma
 Design: DO (South)

Rajesh
 Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Design: ADO (BCP)

CFO (HO)

Vijay
 6/31/2023
 Director
[Signature]
 9/03/23

ADP BCP
ADP/FR
one

As approved, F.T. letter is prepared and put up for kind perusal, Sign for.
Jadhav
 6/3/23

Director, DFA
 7/07/23
mu

uploaded
[Signature]
 7/3/23