

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

C-100

No.F6/DFS/MS/GH/2023/ 59

Dated 09/03/2023

FIRE SAFETY CERTIFICATE

Certified that **The Mount Shiva Dx. Lodge** located at **8531-8534/5, Arakashan Road, New Delhi** is comprised of Basement + Ground + 04 Upper floors, Basement (Storage), Ground floor (Reception + 03 guest rooms), 1st floor (06 guest rooms), 2nd floor to 3rd floor (09 guest rooms at each floor), **4th floor not in use as per affidavit dated 26.09.2019 total 27 guest rooms up to third floor only** was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/2020/64 dated 18/02/20 total 27 guest rooms up to third floor only. Now, the premises was re-inspected by the officer concerned of this department on 01/03/23 in the presence of **Sh. Vinod Kumar** and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, (Sub Division-A-1) Basement (Storage), Ground floor (Reception + 03 guest rooms), 1st floor (06 guest rooms), 2nd floor to 3rd floor (09 guest rooms at each floor) total 27 guest rooms upto third floor only**, with effect from 09/03/2023..for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 09/03/2023.....at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service
4.

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi: to kindly ensure the occupancy as detailed above.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. Online id no. 2023021602140 dated 16.02.2023.
3. The Manager, The Mount Shiva Dx. Lodge, 8531-8534/5, Arakashan. Road, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and deviation in construction etc. any shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

M/37

INSPECTION REPORT

1. Name & address of the building The Mount Shiva Dx. Lodge located at 8531-8534/5, Arakashan Road, New Delhi.
2. Type of Occupancy B + Gr. + 04 Upper floors (total 27 Guest rooms) Basement (Storage), Ground floor (Reception + 03 guest rooms), 1st floor (06 guest rooms), 2nd floor to 3rd floor (09 guest rooms at each floor). 4th floor not in use as per affidavit dated 26.09.2019.
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/GH/2020/64 dated 18/02/20.
5. Fire safety directives No.- N/A
6. Date of inspection:- 01/03/23
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Sh. Vinod Kumar
9. Year of construction:- 2001
10. Applicant's letter No:- Online id no. 2023021602140 dated 16.02.2023.
Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1. Access to Building				
	1) Road width	N/A	04 mtr.	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2. Number, Width Type & Arrangement of Exits				
A. Number of staircases				
	1. Upper floors	01	01	MR
	2. Basements	02	02	MR
B. Width of staircase				
	1. Upper floors	1.5 mtr.	1.5 Mtr.	MR
	2. Basements	1 & 1.5 mtr.	1 & 1.5 Mtr. (Iron)	MR
C. Protection of exits				
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	01 mtr.	1.5 mtr.	MR
	F. Door size	01 mtr.	01 mtr.	MR
3. Compartmentation				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4. Smoke Management System				
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	exhaust fan	MR

6

5.	Fire Extinguishers			
	1) Total numbers	08	10	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO type	Required	Provided	MR
	2) Location of main panel	Ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	At each floor	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA			
		Required	Provided	MR
9.	Public Address System			
		Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	N/A	N/A	N/A

✓

N/39

	capacity			
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 ltr.	5,000 ltr. ✓	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			MR
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. No. F6/DFS/MS/GH/2020/64 dated 18/02/20, under rule 35 of the Delhi Fire Service rules 2010 up to third floor only, Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

[Signature]
3/3/23

Name :- Ravinder Singh
Designation :- ADO (CC)

[Signature]
3/3/23

[Signature]
3/3/23

[Signature]
04/03/23

C.F.O. *[Signature]*
6/3/2023

Director *[Signature]*
11/03/23

[Signature]
ADCC