

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO.F6/DFS/MS/WZ/2023/CNG/134

Dated: 09 / 03 / 2023

FIRE SAFETY CERTIFICATE

Certified that the **CNG Filling Station (IGL) at Rohini, Sector-27, Delhi-110085**, comprised of **Single Story Building** owned / occupied by **Indraprastha Gas Limited** was granted NOC by this department vide letter no **F.6/DFS/MS/2020/CNG/109 Dated 19.02.2020**. The premises was re-inspected by officer concerned of this department on **23.02.2023** in the presence of **Mr. Prashant Kumar Saini (Deputy Manager)** and found that the premises have deemed complied with the fire prevention and fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and the building/ premises is fit for occupancy **CNG Filling Station Group 'J'** with effect from 09/03/2023 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010 subject to conditions printed below.

Issued on09/03/2023.....at New Delhi by


(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to:

1. Sh. Ajay Khatri (DGM (Fire & Safety) IGL Bhawan Plot No.4, Community Centre, R.K. Puram, Sector-9, New Delhi-110022.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use for land if any.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. **The conditions as mentioned in letter no F5/(3A)/DFS/CNG/BP/2010/269 dated 09/09/2010 shall be followed strictly.**
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The is available on

N/15

INSPECTION REPORT

1. Name & address of the building : CNG Filling Station(IGL) at Rohini, Sector-27, Delhi-85
 2. Type of Occupancy : CNG Filling Station Group "J"/ Business
 3. Type of Case : Renewal
 4. Details of Previous NOC : F6/DFS/MS/2020/CNG/109 Dated 19.02.2020.
 5. Fire Safety directives letter No : F5/(3A)/DFS/CNG/BP/2010/269 dated 09/09/2010
 6. Date of inspection : 23.02.2023
 7. Name of Inspecting Officer : A.K. Sharma ADO (Rohini)
 8. Name and designation of officers
 From the building side : Mr. Prashant Kumar Saini (Deputy Manager)
 9. Year of Construction : 2010
 10. Applicant's letter No. : IGL/F&S/2022/15/39/1 Dated 13.12.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC /35(6) Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required NA NA	30 mtr NA NA	M/R NA NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	01 NA	01 NA	MR NA
	e. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	1.25 mtr NA	Provided NA	MR NA
	f. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A N/A	NA NA NA	NA NA NA
	d. No. of continuous staircases to terrace	N/A	NA	NA
	e. Width of Corridor	N/A	NA	NA
	f. Door Size	1.0 mtr	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	N/A N/A	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	7.5 Kg-02 10 Kg-07 ISI marked	Provided DCP type Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 m 5 mm	N/A N/A N/A	NA NA NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A N/A	N/A N/A	N/A N/A

(Handwritten signature)

	<ul style="list-style-type: none"> • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Ground Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Power Supply 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NA	NA	NA
14.	Captive Water Storage for firefighting			
	<ul style="list-style-type: none"> • Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication In lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	NA	NA	NA

N/17

	<ul style="list-style-type: none"> Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	Buckets filled with sand, No smoking board were found displayed in Hindi & English. No loose electric wiring were seen in premises & CO2 flooding system found provided		MR
21.	DCP spray system for cascade	Provided		MR

The fire protection systems provided in the building premises were test checked and found functional at the time of inspection.

in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the DFS rules of NOC issued vide letter no. F6/DFS/MS/2020/CNG/109 Dated 19.02.2020, renewal under rule 37 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

DO (NW)

01/03/2023

EFO (D.P. Bhagelwasi)

06/06/2023

CFO
3/07/2023

Director

01/08/2023

11/17

~~Ajay Rohini~~

FT letter is put up for kind perusal and signature please.

Director 01/03/23

19/3/23