



No. F6/DFS/MS/School/WZ/2023/180

Dated: 14/03/2023

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidyalaya (ID-1617011)** Located at **B-3, Paschim Vihar, New Delhi-110063**, comprised of 03 Blocks, BL-1=Ground Floor, BL-2=Ground + 01 Upper Floor & BL-3=Ground + 02 Upper Floors only was issued Fire Safety Certificate by this department Vide Letter No. **F6/DFS/MS/School/WZ/2020/28 Dated 27.01.2020**. The said premise was re-inspected by the officer concerned of this department on 25.02.2023 in the presence of Ms. Anju Kumari (H.O.O) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance as per D.O.E. Cr. No. 3298-3398 dated 01.03.2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from **14/03/23** for a period of **three years**, subject to compliance of the conditions, printed below.

Issued on **14/03/23** at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Sarvodaya Kanya Vidyalaya (ID-1617011), B-3, Paschim Vihar, New Delhi-110063.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

14-18

1. Name & address of the building: **Sarvodaya Kanya Vidyalaya** Located at **B-3, Paschim Vihar, New Delhi-110063**
2. Type of Occupancy : Educational, 03 Blocks (BL-1=Ground Floor, BL-2=Ground + 01 Upper Floor & BL-3=Ground + 03 Upper Floors only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2020 dated 27.01.2020
5. Fire Safety directives Letter No. : DOE Cr. No. 3298-3398 dated 01.03.2011
6. Date of inspection : 25.02.2023
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Ms. Anju Kumari (H.O.O)
9. Year of Construction : 1979
10. Applicant's letter No. : Email dated 16.01.2023

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E Cr. No. 3298-3398 dated 01.03.2011/as per FSC dated 27.01.2020	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> 05 m 350 cm NA 	<ul style="list-style-type: none"> MR (Old Case) MR (Old Case) NA
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements b. Width of staircases • Upper floors • Basements c. Protection of exits • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	<ul style="list-style-type: none"> BL-2=1 BL-3=2 NA 1.5 m NA NA NA NA NA 1.5 mtrs. 01 m 	<ul style="list-style-type: none"> BL-2=02 BL-3=03 NA BL-2=1.45 m x 2 BL-3=1.50 m x 2 & 1.20 m x 1 NA NA NA NA 235 cm & 152 cm 01 m & 94 cm 	<ul style="list-style-type: none"> MR NA NA MR NA NA NA MR MR (Old Case) NA NA NA NA NA NA MR MR MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 29 nos. ABC & CO₂ ISI marked 	<ul style="list-style-type: none"> 30 nos. Provided Provided 	<ul style="list-style-type: none"> MR MR MR

A

C

J

11.28

6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02	Provided	MR
		30 m	Provided	MR
		05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	100 mm	NA
		NA	02	NA
		NA	Provided	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	450 lpm x 2	MR
		40Mtr	Provided	MR
		Required	Provided	MR
	Required	Provided	MR	
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000Ltrs.	Provided.	MR
15	Exit Signage			
		Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply			
		NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> Detector system panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

Handwritten mark

Handwritten mark

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety requirements as per D.O.E. Cr. No. 262-362 dated 17.01.2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2020 dated 27.01.2020 is recommended.

Aman Kumar Lathar
 28/2/23
 Aman Kumar Lathar
 ADO (JWP)

D.O. (WEST)/577
 DATED... 01/03/23

DO (W)

DO
 01/03

DO (DPB)
 27/2/2023

CAO
 3/2/2023

Director
 MV
 01/03/23

FIPK

For JWP
 Sir, R.F. letter is put-up for your signature pl.

Director
 1/3/23

Aman Kumar Lathar
 13/2/23
 ADO (JWP)

m