

C-38

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2023/ 172

Dated: 14/03/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Jaspal Kaur Public School** located at 'B'- Pashchimi, Shalimar Bagh, Delhi- 110088, comprised of Basement, Ground plus three Upper Floors, was issued fire safety certificate vide letter No. F6/DFS/MS/WZ/School/2020/129 dated 19.03.2020. The school building was re-inspected by the officer concerned of this department on 02.03.2023 in the presence of Sh. L.K. Yadav and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 14/03/2023 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on ...14/03/2023... at New Delhi by.

  
(Atul Garg)  
Director

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Jaspal Kaur Public School, 'B'- Pashchimi, Shalimar Bagh, Delhi- 110034.

9c  
10/13/23

2/8

**INSPECTION REPORT**

1. Name & address of the building : Jaspal Kaur School, 'B'- Pashchimi, Shalimar Bagh, New Delhi- 110088.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/WZ/School/2020/129 dated 19.03.2020
5. Fire Safety directives letter No : N/A
6. Date of inspection : 10.02.2023
7. Name of the Inspecting Officers : M.K. Chattopadhyay, Divisional Officer (West)
8. Name and designation of officers from the building side : Sh. L K Yadav
9. Year of Construction : 1987
10. Applicant's letter No. : E-mail dated 14.02.2023

The said school building is comprised of basement, ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 of DFS Rules 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Provided (06 mts)	MR
	• Gate width	Accessible	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	GF – Terrace- 03 GF-FF- 02 + Ramp	Provided	MR
	• Basements	02	02	MR
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts each	GF – Terrace- 1.55, 1.45, 1.40 mts, GF-FF- 1.40 mts x 02 nos., Ramp- 2.20 mts,	MR being old case
	• Basements	1.5, 1.0 mts	1.15, 1.07 mts	MR being old case
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	Provided	MR
	g. Width of Corridor	2.0 mts	2.35 mts	MR
	h. Door Size	1.0 mt, Activity Hall (1 <sup>st</sup> Floor)- 2.0 mts	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	Required	Exhaust fan provided	MR ✓
	• Upper floors	Required	Natural ventilation provided	MR ✓



Exit Signage.		Required	Provided	MR
16	<b>Provision of Lifts.</b>	<b>Not Applicable</b>		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers provided near elect. panel	N/A

The fire protection systems provided in the building were randomly test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, renewal of the NOC issued vide letter No. F.6/DFS/MS/WZ/School/2020/129 dated 19.03.2020, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

D. WEST/58/198  
DATED...6/3/2023

CFD (D.P.B)  
7/3/2023

CFD  
7/3/2023  
Director  
9/3/23

(M.K. CHATTOPADHYAY)  
Divisional Officer, (West)  
06/3/2023