





No. F6/DFS/MS/2023/EH/ ११

Dated: 13 / 03 / 2023

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Curfew Cafe located at Plot No. 2/10, Second Floor, Roop Nagar, Delhi-110007 in the building comprised of ground and 03 upper floors owned/occupied by M/s Curfew Cafe have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 02.03.2023 in the presence of Sh. Luv and that the building/premise is fit for occupancy Class- "D Assembly" (Restaurant) for Second Floor Only with effect from 13/03/23 for a period of 03 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...13...03...23 at New Delhi by

  
(Ajil Garg)  
Director  
Ph-011-23414000  


Copy to:-

1. The Manager, M/s Curfew Cafe located at Plot No. 2/10, Second Floor, Roop Nagar, Delhi-110007.

**Conditions for the validity of Fire Safety Certificate:**

1. This Fire Safety Certificate is valid only for restaurant at second floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
4. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of firefighting system.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : M/s Curfew Cafe at Plot No. 2/10, Second floor, Roop Nagar, Delhi-110007.
2. Type of Occupancy : Assembly/ Restaurant
3. Composition of building : Ground & 03 upper floors but restaurant proposed at 2<sup>nd</sup> floor only,  
Ground floor –Bank, first floor & third floor- vacant
4. Type of Case : New case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 02.03.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers  
from the building side : Sh. Luv
10. Year of Construction : 2019
11. Applicant's letter No. : Online MHA Portal I'd No.2023021401996 Dated: 17.02.2023
12. Covered area of the restaurant : 2<sup>nd</sup> floor covered area-157 Sqm

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	06m	MR
	• Gate width	4.5	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
e. Width of Corridor	NA	NA	NA	
f. Door Size	1.50m	Provided	MR	
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Exhaust Fan	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	06nos	08nos	MR
	• Types	ABC & Co2	ABC- 08	MR



		Yes	Yes	MR
	<ul style="list-style-type: none"> <li>• ISI marking</li> </ul>			
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30m	30m	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Smoke	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	2 <sup>nd</sup> floor	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	2 <sup>nd</sup> floor	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	NA	Provided	NA
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	Required,01	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	01	01	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	01	01	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level                             <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Terrace level                             <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	450lpm	450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
	14	<b>Captive Water Storage for fire fighting.</b>		
<ul style="list-style-type: none"> <li>• Underground tank capacity</li> </ul>		NA	NA	NA
<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>		NA	NA	NA
<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>		NA	NA	NA
<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>		Required	Provided	MR
<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>		20,000 LTR	Provided	MR
		Required	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

Handwritten marks and signatures at the bottom of the page.

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

~~DO/NW~~

~~03/03/2023~~

~~EFO / D.P. Bhargava~~

~~6/31/2023~~

~~CFO~~  
~~6/31/2023~~

~~Dinedar~~  
~~6/03/23~~ #112

~~ADY RN~~

Signature of the Inspecting Officer  
Name :- C.L. Meena  
Designation:- ADO/RN