

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2023/ 141

Dated : 14/03/2023

FIRE SAFETY CERTIFICATE

Certified that the **Auditorium Hall at 4,5,6th floor** of "C" Block building comprises of Basement, Ground + 05 Upper floors at Dr. SPM Civic Centre Minto Road, J.L.N Marg, New Delhi was earlier granted FSC by this department vide letter No.F6/DFS/MS/NDZ/2020/122 dated 28/02/2020.. Now, the premises was re-inspected by the officers concerned of this department on 07/03/2023 in the presence of **Sh. Ashawan Kumar Tyagi (AE) & Subhodh Singh (JE)** and found that the auditorium has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises at 4th, 5th & 6th floor is fit for occupancy class **Assembly Building(Auditorium)** with effect 14/03/2023 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 14/03/2023 at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner , MCD , Civic Center, New Delhi.
2. The Joint Commissioner of Police (Lic.), 1st floor, Police Station Defence Colony, New Delhi.
3. The Project Manager (Electrical) , MCD ,22nd floor ,Dr. SPM Civic Centre Minto Road, J.L.N Marg, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

N/103
INSPECTION REPORT

1. Name & address of the building : Auditorium Hall at 4,5,6th floor of "C" Block in Dr. SPM Civic Centre Minto Road, J.L.N Marg, New Delhi
2. Type of occupancy : Assembly Building – at 4,5& 6th floor of Basement, Ground + 06th upper floors
3. Type of case:- : Renewal
4. Details of previous FSC : F6/DFS/MS/NDZ/2020/122 dated 28/02/2020.
5. Fire safety directives No. : N/A
6. Date of inspection:- : 06/03/2023
7. Name of the inspecting officer : Sh. Rajinder Atwal (DO/CD) & Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer From the building side : **Sh. Ashawan Kumar Tyagi (AE) & Sh. Subhodh Singh (JE)**
9. Year of construction : 2010
10. Applicant's letter No : e-mail id <garghimanshu1986@gmail.com. dated 17.02.2023

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	12 mtr. ✓	MR
	2) Gate width	05 mtr.	06 mtr.	MR
	3) Width of internal road	06 mtr.	06 mtr. ✓	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	06 Nos.	08 Nos. ✓	MR
	2. Basements	NA	NA	NA
	B. Width of staircase			
	1. Upper floors	2 nos. 02 mtr. & 4nos. 1.25 mtr. & 2 nos. 1 mtr.	2 nos. 02 mtr., 1 no. 1.5 mtr. & 3 nos. 1.25 mtr. & 2 nos. 1 mtr. ✓	MR
	2. Basements	NA	NA	NA
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	06 nos.	08nos.	MR
	E. Width of corridor	2 mtr.	2 mtr. ✓	MR
	F. Door size	2 mtr.	2 mtr. ✓	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	NA	NA	NA
	5) Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	120 Nos.	120 Nos. ✓	MR
	2) Types	ABC, CO2,	ABC, CO2,	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			



N/100

	1) Total number	04	04 /	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location			
8.	MOEFA	Required	Provided /	MR
9.	Public Address System	Required	Provided /	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 MM	150 MM /	MR
	2) Total Number of hydrants	04	04 /	MR
	3) Hose box each floor	04	04 /	MR
12.	Yard Hydrants			
	1) Total number of hydrants	09	09 /	MR
	2) Hose box	09	09 /	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM /	MR
	b) Head of main pump	150 mtr.	150 mtr. /	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put	180 LPM	180 LPM /	MR
	e) Jockey pump head	70, 110 & 45 mtr.	70, 110 & 50 mtr.	MR
	f) Stand by pump output	2850 LPM	2850 LPM /	MR
	g) Stand by pump head	150mtr.	150mtr. /	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	2,00,000 ltr.	3,00,000 ltr. /	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided /	MR
	d) Over head tank capacity	30,000 ltr.	30,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR

✓ 20

N/105

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	Required	Provided	MR
	b) Pressurization of lift lobby	Required	Provided	MR
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	Required	Provided	MR
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the auditorium of C block building were randomly tested, checked functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/NDZ/2020/122 dated 28/02/2020 under rule 35 of the Delhi Fire Service rules 2010, Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer


9/3/23

Name :- Rajinder Atwal
Designation :- DO (CD)

Signature of the Inspecting Officer


9/3/23

Name :- Ravinder Singh
Designation :- ADO (CC)

~~Dy. Chd. (C-2)~~ ~~Dir. P~~
~~10/03/23~~

~~C.F.O.~~ ~~13/03/2023~~

~~Director~~ ~~17/03/23~~

~~14/3/23~~ ~~14/03/23~~

F.T letter is put up for
signature please
~~Director~~ ~~14/03/23~~