



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-30
7-
आजारी
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2023/183

Dated: 16/03/2023

FIRE SAFETY CERTIFICATE

Certified that the **S. D. M. Sec. Model School** Located at **Block-D, Ranjit Vihar, Chander Vihar, Nilothi Extn. New Delhi-110041**, comprised of Two blocks i.e. Ground + 02 Upper Floor & Ground + 01 Upper Floor only owned/occupied by S.D.M. Sec. Model School was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/2018/WZ/1034 Dated 11.05.2018. The said premise was re-inspected by the officer concerned of this department on 27.02.2023 in the presence of Dr. Yogesh Mehta (Manager) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17.01.2005 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 16/03/2023 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010., printed below

Issued on 16/03/2023 at New Delhi by.

(Anil Garg)
Director

Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, S.D.M. Sec. Model School, Block-D, Ranjit Vihar, Chander Vihar, Nilothi Extn. New Delhi-110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

2-18

1. Name and address of the building: **S.D.M. Model Public School Located at D-Block, Ranjit Vihar, Chander Vihar, Nilothi Extn. New Delhi-110041.**
2. Type of Occupancy : Educational, 02 Blocks, Ground + 01, Ground + 02 Upper Floor only (interconnected to each other)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/WZ/1034 Dated 11.05.2018
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 262-362 dated 17.01.2005
6. Date of inspection : 27.02.2023
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Dr. Yogesh Mehta (Manager)
9. Year of Construction : 1989
10. Applicant's letter No. : email dated 02.02.2023

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 262-362 Dated 17.01.2005/ as per FSC dated 11.05.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02 at (G+2) 01 at (G+1)	MR being old case ✓
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	G+2-1.30 m x 1 & 1.09 m x 1 G+1-0.98 m x 1	MR being old case ✓
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

N-19

5.	Fire Extinguishers	10 nos. ABC & CO ₂ ISI marked	Provided	MR
	<ul style="list-style-type: none"> Total numbers Types IS marking 		Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	100 mm	NA
		NA	01	NA
		NA	Provided	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		3,000 ltrs. (old case)	3,000 ltrs.	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings issued vide letter no F6/DFS/MS/School/WZ/2023/50 dated 01.02.2023 are rectified.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 262-362 dated 17.01.2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2018/WZ/1034 Dated 11.05.2018 is recommended.

Accordingly DFA is put up for approval please.

Amita
05/05/23
Aman Kumar Lathar
ADO (JWP)

D.O. (WEST) 554
DATED 6/5/23

DO/50
8/6/23
CFB (DPPB)
7/5/2023
CFB
7/28/2023
Director
9/03/23

Director
14/07/23
Am, r.s. letter is put-up for signature 1st.
Amita
15/3/23
ADO (JWP)