

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/ 151

Dated: 21/03/2023

FIRE SAFETY CERTIFICATE

Certified that the Aquatic training facility in residential cum training complex, Located at Plot No. 21, Sector - 21, Dwarka, New Delhi comprised of Ground & 1st Floor owned/ occupied by SPG have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the team of officers concerned of this department on 13/03/2023 & 17/03/2023 in the presence of Sh. K.P Yadav (AIG, SPG), Sh. Atul (AE/ DDA) & Sh. Shahrookh Ali (AE/DDA) and found that the said premises is fit for occupancy class 'D' "Assembly Building" (Swimming Pool) with effect from 21/03/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....21/03/2023.....at New Delhi by.

Yours faithfully,


(Atul Garg)
Director,
Delhi Fire Service.

Copy to:

1. The Director (Bldg.), Delhi Development Authority, C-1, 1st floor, Vikas Sadan, INA, New Delhi - 110023
2. Sh K P Yadov, AIG(SPG), Aquatic training facility in residential cum training complex, Located at Plot No. 21, Sector - 21, Dwarka, New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Aquatic training facility in residential cum training complex, Located at Plot No. 21, Sector – 21, Dwarka, New Delhi.
2. Type of Occupancy : Assembly (**Ground & 1st Floor**)
3. Type of Case : New (Swimming Pool)
4. Details of previous NOC: Nil
5. Fire Safety directives L. No. : Nil
6. Date of inspection : 13/03/2023 & 17/03/2023
7. Name of the Inspecting Officer : DO/SW &ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. K.P Yadav (AIG) Sh. Atul (AE/ DDA) ,
& Sh. Shahrookh Ali (AE/DDA)
9. Year of Construction : 2022
10. Applicant's letter No. : F13(03)17/Bldg/75, dated 17/02/2023
& Email dated 17/03/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per NBC/BBL	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	Provided	MR
	• Gate width	05 mtrs	Within the campus of SPG	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2x1.5 m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA



5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	Required. ABC, WCO2 & CO2 ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA.	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements: Common with SPG Pump House			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	2250 lpm	NA
		NA	70 mtr	NA
		NA	2	NA
		NA	180lpm	NA
		NA	70mtr	NA
		NA	2250lpm	NA
		NA	70mtr	NA
		NA	Provided	NA
		NA	Provided	NA
		450 lpm	Not Provided	MR (Pump at ground level at higher side)
		40Mtr	Not Provided	--do--
		Required	Not Provided	--do--
		Required	Not Provided	--do--
14	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	300,000 ltrs	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		20,000 Litres	Not Provided	MR(Tank at G. level at higher side)
15	Exit Signage	Required	Provided	MR

(Handwritten signature)

N/14

16	Provision of Lifts			NA
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

[Handwritten Signature]
18/3/23

Signature of the Inspecting Officer
Name: Sh. Vedpal
Designation: DO/SW

[Handwritten Signature]
18/3/23

Signature of the Inspecting Officer
Name: Udai Vir Singh
Designation: ADO/DWK

[Handwritten Signature]
20/03/2023

[Handwritten Signature]
21/03/23

[Handwritten Signature]

AT P/S

Sir AT letter is put up for sign ble

[Handwritten Signature]
21/03/23

[Handwritten Signature]
21/3/23