

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/Bnqt./2023/NDZ/ 13

Dated: 20/03/2023

Certified that the **Royal Banquet** located at 162/22, Jheel Khuranja, Near Ramila Ground, Delhi-110051, comprised of ground plus one upper floor, owned/occupied by **Royal Banquet** was issued FSC vide letter No. F.6/DFS/MS/NDZ/2018/BNQT/56 dated- 08/01/2018. The premises was re-inspected by the officer concerned of this department on dated 03/03/2023 in the presence of Mr. Dheeraj Bindra and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and observed that the building/premises is fit for occupancy **Group D "Assembly"** with effect from 20/03/2023 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on... 20/03/2023at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To,

1. The Manager
Royal Banquet at 162/22, Jheel Khuranja, Near Ramila Ground, Delhi-110051
2. The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony, New Delhi
MHA ID No. 2023012501115


Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Royal Banquet, 162-22, Jheel Khuranja, Delhi-110051
2. Building is comprised of : Ground plus one upper floor
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/NDZ/2018/BNQT/56 dated- 08/01/2018
6. Fire Safety direction letter No. : NBC Part-IV
7. Date of Inspection : 03/03/2023
8. Name of the Inspecting officers : ADO Deepak Kumar
9. Name and designation of Officer from the building side : Sh. Dheeraj Bindra
10. Year of Construction : 1991
11. Applicant's letter no. : 2023012501115 dated-25/01/2023

Sr. No	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building	-		
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 m N/A N/A	30 m N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	02 nos. N/A	02 nos. ✓ N/A	MR N/A
	b. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	1.5 m N/A	1.5 m each ✓ N/A	MR N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of Continuous Staircases to Terrace	02 nos.	02 nos. ✓	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 m	02 m	MR
	g. No of door	02 nos.	02 nos.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A Required	N/A Ventilated	N/A MR
05.	Fire Extinguishers	-		
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06 nos. ABC /CO ₂ ISI marked	08 nos. ABC/Co ₂ ISI marked	MR MR MR




06	First-Aid-Hose Reels.			
	• Total numbers on each floor	01 nos.	01 nos.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	40m	40m	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
	•			
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 Ltr.	10,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR

R. J. J. S. S.


16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR ✓
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. Declaration letter attached given by owner for roof tin shad.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F.6/DFS/MS/NDZ/2018/BNQT/56 dated- 08/01/2018 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.



06/03/2023.
Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- ADO(Shah.)

~~DO (ED)~~ DFA pl.


07/03/2023

~~By CFO (NDZ)~~


07/03/23

C.F/O.

10/31/2023

Director

10/23/23


AOC (Shah.)