

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/School/2023/SZ/201

Dated: 21/03/2023

FIRE SAFETY CERTIFICATE

Certified that the **St. Paul's School** at C-3, Safdarjung Development Area, New Delhi 110016 comprised of Basement, ground plus three upper floors owned/occupied by St. Paul's School was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2017/SZ/1542 Dt. 27/10/2017. The said premises was re-inspected by officer concerned of this department on 14/03/2023 in presence of Mr. Thomas P.T (Admin) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "Educational Building Group - B" with effect from 21/03/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 21/03/2023 at New Delhi by

**ATUL GARG
DIRECTOR
DELHI FIRE SERVICE**

Copy to: -

1. The Principal, St. Paul's School at C-3, Safdarjung Development Area, New Delhi 110016.
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept unlocked and free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL /NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	St. Paul's School at C-3, Safdarjung Development Area, New Delhi 110016		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Basement + Ground + 3 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2020/SZ/206 dated 26/06/2020		
6	Fire Safety Directives Letter No	DOE dated 17/01/2005 ✓		
7	Date of Inspection	14.03.2023		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr Thomas P T (Admin)		
10	Year of construction	2006		
11	Applicant letter No.	Outdoor diary no 10902 dated 06-02-2023		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	10 m	MR
	• Gate width	Required	3.6 mtr	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	➤ Upper floors.	04 Nos	05 Nos	MR
	➤ Basement floor.	02 Nos	02 Nos	MR
	b. Width of Staircase			
	➤ Upper floors	Required	1.50m, 1.45m, 1.45m, 1.10m & 1.06m	MR
	➤ Basement floor	Required	1.45m & 1.45m	MR
	c. Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	Required	Three	MR
	e. Width of corridor	NA	NA	NA
	f. Door size	1.0 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	12 ACPH	Exhaust fan provided	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	15 Nos	Provided	MR
	• Types	ABC / Co2	ABC- 15	MR
	• ISI Marking	Required	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	03 No	03 Nos	MR
	• Length of hose-reel hose.	30 mtr	provided	MR
	• Nozzle Diameter	5 mm	provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	NA	NA	NA

↑


✓

mw

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100mm	Provided	MR
		03 Nos	Provided	MR
		03 Nos	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	NA	NA	NA
		NA	NA	NA
13.	Pumping arrangements.			
	A. Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting / Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	B. Terrace Level			
	➤ Discharge of pump.	450 & 180 LPM	450 LPM x 2 & 180 LPM	MR
	➤ Head of pump.	35 mtr each	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 Ltr	15,000 ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. Flow switch panel. 	NA	NA	NA
		NA	NA	NA

2

3

	• PA system panel.	NA	NA	NA
	• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.			NA
	The fire protection system provided in the building were randomly checked and found functional at the time of inspection.			
	Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2017/SZ/1542 Dt. 27/10/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.			
	Accordingly, DFA is put up for approval and signature please.			
	<div style="text-align: right;">  Signature of the Inspection Officer Name: Sh. Rajesh Kumar Design: ADO (BCP) </div>			

DO (SD)

msb
15/3

cpa
16/3/2023

Director
17/3/23

f 15/3

Any/BLD

As approved, F.T. letter is put up for
your signature pl.

18/3/23

Director
21/3/23

ms