

C 10

DFA

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2023/198

Dated: 20/03/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Dr. B. R. Ambedkar School of Specialised Excellence, Sector-18, Rohini, Delhi (School ID-1310469)**, comprised of **Ground + 03 upper floors & 01 MP Hall in 2<sup>nd</sup> floor** owned/ occupied by **Dr. B. R. Ambedkar School** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on dated **18.02.2023** in the presence of **Er. Shashank Sahu Assistant Engineer (E)** and that the building/ premise is fit for occupancy **Group B Educational** with effect from **20/03/2023** for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/03/2023 at New Delhi by

  
(Atul Garg)  
**DIRECTOR**  
Ph; 011-23414000

**Copy to:**

1. The Principal, Dr. B. R. Ambedkar School of Specialised Excellence, Sector-18, Rohini, Delhi (School ID-1310469).
  2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054
- Conditions for validity of Fire Safety Certificate;**
1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
  2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
  3. The trained fire fighting staff should be available round the clock.
  4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
  5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
  6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
  7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
  8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_t\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

### INSPECTION REPORT

1. Name & address of the building : Dr. B. R. Ambedkar School of Specialised Excellence, Sector-18, Rohini, Delhi (School ID-1310469).
2. Type of Occupancy : Educational
3. Type of Case : New Case (Ground + 03 upper floors & 01 MP Hall in 2<sup>nd</sup> floor)
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2021/School/216 dated 25.04.2021 issue for name of Govt. Senior Secondary School).
6. Date of inspection : 18.02.2023
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers  
From the building side : Er. Shashank Sahu Assistant Engineer (E)
9. Year of Construction : 2022
10. Applicant's letter No. : OD No.10071 dated 13.01.2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	6m	12m	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	06	06	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	2.0m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	06	06	MR
	e. Width of Corridor	1.5m	2.4m	MR
	f. Door Size	1.20m	Provided	MR
	MP Hall	2 x 2.0m	2x 2.0m	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	50nos.	80nos.	MR
	• Types	ABC/CO2	ABC-40/CO2-40	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA

*Handwritten signature and initials*



n/3

• Battery backup	NA	NA	NA
• Building Floor Plans			
Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*Amyr*  
 7/8/23  
 Signature of the Inspecting Officer  
 Name Ajay Kumar Sharma  
 Designation ADO(Rohini)

~~DO (NW)~~  
*Amyr*  
 09/03/2023

CFO I.D.P. Bhardwaj  
*[Signature]*  
 10/3/2023

CFO *[Signature]*  
 10/03/2023

~~Director~~ *[Signature]*  
 10/03/23

~~Any text~~

FT letter is put up for kind perusal and signature please.

~~Director~~ *[Signature]*  
 17/03/23

*Amyr*  
 17/3/23