



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE NEW DELHI - 110001**

No.F6/DFS/MS/CNG/2023/160

Dated: 28/03/2023

FIRE SAFETY CERTIFICATE

Certified that the CNG Station (Hybrid) at Gazipur DTC Depot, Delhi comprised of Ground floor only owned / occupied by Indraprastha Gas Limited, was issued FSC vide letter No. F6/DFS/MS/CNG/2020/553 Dated 30/12/2020. The premises was re-inspected by the officer concerned of this department on 13/03/2023 in presence of Sh. Anurag Mishra and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rule, 2010 and that the building is fit for occupancy class "Hazardous" Group-J with effect from 28/03/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 28/03/2023 **at New Delhi by.**


(APUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Addl. Commissioner (Licensing), 1st Floor, Police Station Defence Colony, New Delhi.
2. Sh. Ajay Khatri, DGM (Fire & Safety), Indraprastha Gas Ltd., IGL Bhawan, Plot No. No. 4, Community Centre, R.K. Puram, Sector-9, New Delhi-110022.
3. The Depot Manager (GPD), D.T.C. Gazipur Depot, Delhi - 96.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1/30

1. Name & address of the building CNG Station (Hybrid) at Gazipur DTC Depot, Delhi-110096.
2. Type of occupancy:- Hazardous Group J
Single story building
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/CNG/2020/553 dated 30/12/20
5. Fire safety directives No.- F6/DFS/MS/CNG/2020/202 dated 16.01.2020
6. Date of inspection:- 13/03/2023
7. Name of the inspecting officer:- A.K. Jaiswal, D.O. (East)
8. Name & designation of officer
From the building side:- Sh. Anurag Mishra
9. Year of construction:- 2020
10. Applicant's letter No:- IGL/F&S/2023/15/126/1 dated 28/02/2023

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	30 mtr.	30 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	06 DCP flooding system, 01 DCP 75Kg, 01 water mist trolley, 2 Co2 flooding system 45 Kg, 02 DCP 9 Kg, 2 Co2 4.5 Kg.	06 DCP flooding system, 01 DCP 75Kg, 01 water mist trolley, 2 Co2 flooding system 45 Kg, 02 DCP 9 Kg, 2 Co2 4.5 Kg.	MR
	2) Types	ABC, CO ₂ , DCP flooding system, water Mist cum foam trolley	ABC, CO ₂ , DCP flooding system, water Mist cum foam trolley	MR
	3) ISI marking	Required	Provided	MR

6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Flame	Provided in Compressor Packager Area	MR ✓
	2) Location of main panel	G.F.	Gr. Floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A

~~20~~ 20

14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: Provided Fire buckers dilled with sand. No smoking bards displayed in Hindi & English electrical wiring in metal conduit. MCB, Co2, flooding system.			MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, The Fire Safety Certificate issued vide letter no. F6/DFS/MS/CNG/2020/553 Dated 30/12/2020 renewal under NBC (Part-IV) is recommended.

Ashok Kumar
13/03/2023

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East. Div.).

Dy. CFO (N/12)

Rimp
14/03/23

C.F.O.

Umesh
15/03/2023

Deneet
16/03/23

DUF/NOL

Rimp
17/03/23

D.T.O.