

C-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2023/ School/NDZ/ 923

Dated 03/04/2023

FIRE SAFETY CERTIFICATE

Certified that the SPS type additional class room block at Sarvodya Kanya Vidyalaya located at Aram Bagh, Pahar Ganj, New Delhi comprises of Ground + 03 Upper floor was inspected by the officer concerned of this department on 17-03-2023 in the presence of Sh. Sandeep Singh Meena, JE (E), PWD and found that the said premises has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group B "Educational Building" Sub-Div. B-I** with effect from 03/04/2023... for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 03/04/2023 at New Delhi by:


(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Assistant Engineer (Electrical) Sub Div.-04 Education Electrical Edu. Div -(N), PWD, Room no 03 first floor, plot no 4, Satguru Ramsingh Marg Rama Road, Zakhira, Delhi -110015.
3. The Principal, Sarvodya Kanya Vidyalaya, Aram Bagh Pahar Ganj, New Delhi.
4. Director of Education, Old Secretariat, Delhi – 110054.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration shall strictly prohibited.

INSPECTION REPORT

1. Name & address of the building:- **SPS type additional classroom block at Sarvodya Kanya Vidyalya located at Aram Bagh , Paharganj, New Delhi**
 Educational Group B-I, Gr.+03 Upper Floor
2. Type of occupancy:-
 3. Type of case:-
 4. Details of previous FSC:-
 5. Fire safety directives No.-
 6. Date of inspection:-
 7. Name of the inspecting officer:-
8. Name & designation of officer
 From the building side:-
 9. Year of construction:-
 10. Applicant's letter No:-
- Sh. Ravinder Singh(ADO/CC)
 Sh. Sandeep Singh , JE (E) PWD
 2023
 e- mail id < ncepedsd4@gmail.com dated
 04.04.2022 & letter no 54(15)A.E.(E)-4PWD/M-1/2022-23/35 dated 04.11.2022 received on dt 07.02.23
 New

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per UBBL-2016 /NBC part-4	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	06 mtr. ✓	MR
	2) Gate width	4.5 mtr.	4.5 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03 Nos.	03 Nos. ✓	MR ✓
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1.6 mtr. each ✓	MR ✓
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02	02	MR
	E. Width of corridor	1.5 mtr.	1.8 mtr. ✓	MR
	F. Door size(class room)	1.20 mtr.	1.20 mtr. ✓	MR ✓
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	24 Nos.	24 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR

e

✓ 6/30

	3) ISI marking	N/A	N/A	N/A
6.	First-Aid Hose Reel			
	1) Total number of each floor	03nos	03 nos	MR
	2) Length of hose reel hose	30 mtr	30mtr	MR
	3) Nozzle diameter	5 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450x2nos lpm	MR
	b) Head of pump	40 mtr	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A


N/114

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10000 liter	20,000 liter	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under DFS Act 2007 & Rules 2010, if agreed, we may issue the FSC to said premises. Accordingly reply letter is prepared and put up for kind perusal and signature pl.

Signature of the Inspecting Officer



Name :- Ravinder Singh
Designation :- ADO (CC)

D/O
22/3/23

Dy. C.S.O.

Rings
23/03/23

C.F.O.
23/03/23
Director
24/03/23

Amu