



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2023/NDZ/918

Dated: 03/04/2023

FIRE SAFETY CERTIFICATE

Certified that the Nav Jeevan Adarsh Sr. Sec School located at Gautam Puri, Delhi-110053, comprised of ground plus two upper floors, owned/occupied by Nav Jeevan Adarsh Sr. Sec School has already been issued FSC vide letter no. F.6/DFS/MS/School/2019/NDZ/253 dated 01/02/2019. The premises was re-inspected by the officer concerned of fire service on 10/03/2023 in the presence of Sh. Praveen Baisala, Manager of the school and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 03/04/2023 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 03/04/2023..... at New Delhi by


(ATUL GARG)
DIRECTOR
OK E DELHI FIRE SERVICE

To,

1. The Principal,
Nav Jeevan Adarsh Sr. Sec School at Gautam Puri, Delhi-110053
2. The Dy. Director of Education,
B-Block, Yamuna Vihar, Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

N/18

1. Name & address of the building : Nav Jeevan Adarsh Public Sr. Sec School
Gautam Puri, Delhi- 110053
2. Building is comprised of : Ground plus two upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DI S/MS/School/2019/NDZ/253 dt 01/02/2019
6. Fire Safety directive letter No : NBC Part IV
7. Date of Inspection : 10/03/2023
8. Name of the Inspecting officers : ADO (Shd). Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Parveen Baisala, Manager
10. Year of Construction : 2005
11. Applicant's letter No : NJAPS/23 dated 03/02/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR NMR
01	Access to Building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 mtr. 4.50 mtr N/A	6.50 mtr 5.25 mtr N/A	MR MR N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	02 nos N/A	03 nos N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	1.50 mtr N/A	1.70 mtr each/ N/A	MR N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	02 no.	02 no.	MR
	e. Width of Corridor	1.50 mtr	03 mtr & 1.80 mtr	MR
	f. Door Size	01 mtr.	01 mtr	MR
03	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A N/A	N/A N/A	N/A N/A
05	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	15 nos ABC /CO ₂ ISI marked	18 nos ABC & CO ₂ Provided	MR MR MR

e. A 20



N/19

06	First-Aid-Hose Reels.			
	Total numbers on each floor	02 nos	02 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 lpm	450 lpm	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 ltr	10,000 ltr	MR
15	Exit Signage	Required	Provided	MR

2/2 50/0

N/20

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule. The FSC issued vide letter No F6/DFS/MS/School/2019/NDZ/253 dated 01/02/2019 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended

Deepak
14/03/2023

Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A D O (Shd)

~~DO (FD)~~ DFA please.

Dy. C.F.O. (NDZ)
Abhishek
20/03/2023
Rin
21/03/23

C.F.O.
Khushi
21/03/2023

~~Director~~
[Signature]
21/03/23

Amisha

Sir, FT letter is for up for your kind signature pl.

Deepak