



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/EH/NDZ/2023/ 115

Dated: 31/03/2023

FIRE SAFETY CERTIFICATE

Certified that the Café Blue Delhi (A Unit of King Café) earlier it was Saffron Court Restaurant, located at Plot No. -8 LSC, New Rajdhani Enclave, Vikas Marg, Delhi-110092. Comprised of Basement + Ground + 02 Upper floors was earlier issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2009/331 Dated 04/02/2009 for ground & 1st Floor Only. Now restaurant is running on 1st Floor only, owned / occupied by (A Unit of King Café) was re-inspected by the officers concerned of this department on 16/03/2023 in presence of Sh. Akash and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 that the building is fit for occupancy class "Assembly" (Group-D) Eating House (1st Floor only), with effect from 31/03/2023 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/03/2023 at New Delhi by


(ATUL GARG)
DIRECTOR

o/c
2
DELHI FIRE SERVICE

Copy to:-

1. The Deputy Commissioner (Licensing), 1st Floor, Police Station Defence Colony, New Delhi.
Online application ID no. 2023022202445 dated 22.02.2023
2. The Manager, Café Blue Delhi (A Unit of King Café), Plot No. -8 LSC, New Rajdhani Enclave, Vikas Marg, Delhi-110092

Condition for the validity of fire safety certificate

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained firefighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
- 9 Any flammable material for interior decoration is prohibited.

N11

INSPECTION REPORT

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Name & address of the building	Cafe Blue Delhi (A Unit of King Cafe) earlier it was Saffron Court Restaurant located at Plot No. -8 LSC, New Rajdhani Enclave, Vikas Marg, Delhi-110092		
2	Type of Occupancy	Assembly Building (Restaurant) Basement, Ground Floor, 1 st Floor & 2 nd Floor. But restaurant is running on 1 st floor only.		
3	Type of Case	Renewal/Alteration (For 1st Floor only)		
4	Details of previous FSC	F6/DFS/MS/EH/2009/331 Dated 04/02/2009 (For Ground & 1st Floor only)		
5	Fire Safety directives Letter No.	N/A		
6	Date of inspection	16.03.2023		
7	Name of the Inspecting Officer	Sh. A.K. Jaiswal (DO/ED) & Sh. Deepak Kumar (ADO/Shah.)		
8	Name and Designation of Officer from the building side	Sh. Akash		
9	Year of Construction	2004		
10	Applicant's letter No./ Online Id No.	2023022202445 dated 22.02.2023		
1	Access to Building			
	1 Road Width	12 mtr	60 mtr	MR
	2 Gate Width	N/A	On Main Road	N/A
	3 Width of Internal Road	N/A	N/A	N/A
2	Number, Width, Type & Arrangements of exits			
	A Number of Staircase			
	1 Upper Floors	01 nos.	03 nos.	MR
	2 Basement	N/A	N/A	N/A
	B Width of Staircase			
	1 Upper Floors	N/A	1.10 x1 & 1.5 x 2	MR(old case) ✓
	2 Basement	N/A	N/A	N/A
	C Protection of Exits			
	1 Fire Check door	Required	Provided	MR
	2 Pressurization	N/A	N/A	N/A
	D No. of Continuous S/C to terrace	N/A	N/A	N/A
	E Width of Corridor	N/A	N/A	N/A
	F Door Size	2 Exit	2 Exit (1.50 x 2)	MR(old case)
3	Compartmentation			
	1 Fire check door	Required	Provided	MR
	2 Sealing of electrical shafts	N/A	N/A	N/A
	3 Fire rating of shaft door	N/A	N/A	N/A
	4 Water curtain	N/A	N/A	N/A
	5 Fire Dampers	N/A	N/A	N/A

P. ~~AA~~ SW C

N/2

4	Smoke Management System			
	1 Basements	N/A	N/A	N/A
	2 Upper floors	Required	Exhaust fan	MR
5	Fire Extinguishers			
	1 Total Numbers	2 Nos.	4 Nos.	MR
	2 Types	ABC & CO2	ABC & CO2	MR
	3 ISI Marking	Required	Provided	MR
6	First-Aid Hose Reel			
	1 Total number 1 st floor	01	01	MR
	2 Length of hose reel hose	30 mtr.	30 mtr.	MR
	3 Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection & Alarming System			
	1 Type of detectors	N/A	Provided	N/A
	2 Location of main panel	N/A	Provided	N/A
	3 Location of repeater panel	N/A	Provided	N/A
	4 Alternate source of power	N/A	Provided	N/A
	5 Hooter's Location	N/A	Provided	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	1 Basement	N/A	N/A	N/A
	2 Upper floors	N/A	N/A	N/A
	3 Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	1 Size of riser/down-comer	N/A	Provided	N/A
	2 Number of hydrants per floor	N/A	Provided	N/A
	3 Hose box	N/A	Provided	N/A
12	Yard Hydrants			
	1 Total number of hydrants	N/A	Provided	N/A
	2 Hose box	N/A	Provided	N/A
13	Pumping Arrangement			
	A Ground level			
	1 Discharge of main pump	N/A	N/A	N/A
	2 Head of main pump	N/A	N/A	N/A
	3 Number of main pump	N/A	N/A	N/A
	4 Jockey pump out put	N/A	N/A	N/A
	5 Jockey pump head	N/A	N/A	N/A
	6 Stand by pump output	N/A	N/A	N/A
	7 Stand by pump head	N/A	N/A	N/A
	8 Auto starting/Manual stopping	N/A	N/A	N/A
	B Terrace level			
	1 Discharge of pump	450 LPM	450 LPM	MR
	2 Head of pump	40 mtr	40 mtr.	MR
	3 Power supply	Required	Provided	MR
	4 Auto starting of pump	Required	Provided	MR
14	Capacity of Water Storage for Fire Fighting			
	1 Underground tank capacity	N/A	N/A	N/A
	2 Draw-off connection	N/A	N/A	N/A
	3 Fire service inlet	N/A	N/A	N/A
	4 Access to tank	N/A	N/A	N/A
	5 Over head tank capacity	5,000 ltr.	20,000 ltr.	MR

2-9/11/20
20/

2

		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	1 Pressurization of lift shaft	N/A	N/A	N/A
	2 Pressurization of lift lobby	N/A	N/A	N/A
	3 Communication in lift car	N/A	N/A	N/A
	4 Fireman's switch	N/A	N/A	N/A
	5 Lift signage	N/A	N/A	N/A
17	Stand by Power Supply	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	1 Detector system panel	N/A	N/A	N/A
	2 Flow switch panel	N/A	N/A	N/A
	3 PA system panel	N/A	N/A	N/A
	4 Battery backup	N/A	N/A	N/A
	5 Building floor plan	N/A	N/A	N/A
20	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, The Fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/2009/331 Dated 04/02/2009 (For Ground & 1st Floor only) renewal under NBC (Part-IV) is recommended for 1st Floor only)

Deepak
16/03/2023
Signature of the Inspection Officer
Name - Deepak Kumar
Designation - ADO/Shah

A K Jaiswal
16/03/2023
Signature of the Inspection Officer
Name - A K Jaiswal
Designation - DO/ED

~~Dy. C.F.O. (N/3)~~ *Riv P*
22/03/22

~~C.F.O.~~ *Khushi*
23/03/2023

~~Director~~ *M*
23/03/22

~~ADP~~ *D/FC/ADL*

Riv P
24/03

~~ADO (Shah.)~~

Sir, F.S. Letter is put up for your kind signature pl.