



75  
Azadi Ka  
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F.6/DFS/MS/EH/2023/NDZ/ 116

Dated: 31/03/2023

FIRE SAFETY CERTIFICATE

Certified that the London Street running at ground floor of the building comprised of basements, ground plus two upper floors located at SG-33,34, 35, 55, 56, 57, Adity Mega Mall, CBD Shahdara, Delhi-110032, owned/occupied by Crudex LNG Petroleum Pvt. Ltd. was issued FSC vide letter No. F.6/DFS/MS/2019/441 dated 28/02/2019. The premises was re-inspected by the officer concerned of this department on dated 22/03/2023 in the presence of Mr. Salil Sehgal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy Group 'D' "Assembly" with effect from 31/03/2023 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 31/03/2023 at New Delhi by

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

To,

1. Sh. Dishan S/o Sh Julfukar  
London Street at SG-33,34, 35, 55, 56, 57, Adity Mega Mall, CBD Shahdara, Delhi-32
2. The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor Police Station, Defense Colony, New Delhi  
MHA ID No. 2022051710505

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building : London Street  
SG-33,34, 35, 55, 56, 57, Adity Mega Mall,  
CBD Shahdara Delhi-110032
2. Building is comprised of :Basement, Ground plus two upper floors  
(Restaurant is running at ground floor only)
3. Type of Occupancy :Assembly (Restaurant)
4. Type of Case :Renewal
5. Details of Previous NOC letter :F.6/DFS/MS/2019/441 dt 28/02/2019
6. Fire Safety directive letter No :NBC Part IV
7. Date of Inspection :22/03/2023
8. Name of the Inspecting officers ADO (Shd.), Deepak Kumar
9. Name and designation of Officer  
from the building side : Mr. Salil Sehgal
10. Year of Construction :2006
11. Applicant's letter No :2022051710505 dated 14/03/2022

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NM/R
01	Access to Building			
	• Road width	12mtr.	30mtr.	MR
	• Gate width	4.50 mtr	06mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2.00 M	2.00 M & 1.60 mtr	MR
	g. Number of Door	02 no.	02 no.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR
05.	Fire Extinguishers			
	• Total numbers	04 nos.	06 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	Provided	MR

2. A 50/



06	First-Aid-Hose Reels.			
	Total numbers on each floor Near restaurant	01 nos	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 no.	Provided	MR
	• Hose box	01 no.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	Provided	N/A
	• Hose box	N/A	Provided	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out pu	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM ✓	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	10,000 ltr	10,000 ltr ✓	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/2019/441 dated 28/02/2019 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Eating House has installed separate fire system, if you agree may considered for Fire Safety Certificate.

*Deepak*  
23/03/2023  
Signature of the Inspecting Officer  
Name : Deepak Kumar  
Designation : ADO (Shd)

~~DO(ED)~~ DFA please.

~~DY. C.F.O. (NDZ)~~

*Approved*  
23/03/2023

~~C.F.O.~~

*Riv*  
24/03/23

~~Director~~

*Mugh*  
24/03/2023

~~Dy. C.F.O.~~  
~~ADO (Shd)~~