



7.12  
11.02  
27/02/23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/MN/Metro/2023 /175

Dated: 06/04/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Pitampura Metro Station (Without PD Area), Elevated (Line -01) located at Pitampura, New Delhi - 110034, comprised of Ground, Concourse & Platform, was issued FSC vide Letter No. F6/DFS/MS/WZ/2019/2018 dated 21/10/2019. The premises was re inspected by the officer concerned of this department on 20/03/2023 in the presence of Sh. Sanyam Jain (AM/Fire) and observed that all the Fire prevention & Fire Safety arrangements provided in the premises found in good working condition. The said metro station have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D Sub Division D-7 (Without PD Area) with effect from 06/04/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/04/2023 at New Delhi by

  
(In Charge)  
Director

Copy to: -

1. Sh. Vivek Srivastava (JGM/E&M), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations/ Addition & Alteration w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

  
25/04/2023



**INSPECTION REPORT**

1. Name & address of the building : Pitampura Metro Station, (Without PD Area) Elevated (Line- 01) Located at Pitampura, New Delhi - 110034.
2. Type of Occupancy : Assembly (Ground, Concourse & Platform)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2019/2018 dated 21/10/2019
5. Fire Safety directives letter No : Nil
6. Date of inspection : 20/03/2023
7. Name of the Inspecting Officers : Sarabjeet Singh (ADO MN)
8. Name and designation of officers from the building side : Sh. Sanyam Jain (AM/Fire)
9. Year of Construction :
10. Applicant's letter No. : E-Mail dated - 06/02/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	On Main Road	Provided	MR
	• Gate width	05 mts	On Main Road	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	Old Case	P-1 to C = 153 cm, 374cm, P-2 to C = 155cm, 391cm	MR (Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	Old Case	Old Case	Old Case
	g. Door Size	Old Case	Old Case	Old Case
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	35	Provided	MR
	• Types	CO2 /ABC	Provided	MR
	• IS marking	ISI marked	Provided	MR





6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	2 on each platform	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150 mm	Provided	MR
		2 on each platform	Provided	MR
		Required	Provided	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	02	Provided	MR
		Required	Provided	MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	All the pumps are connected with generator also		
		1800 lpm	Provided	MR
		60m	Provided	MR
		01	Provided	MR
		180 lpm	Provided	MR
		60 m	Provided	MR
		1800 lpm	Provided	MR
		60m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	50,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
15	<b>Exit Signage.</b>	Required	Provided	MR

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Co <sub>2</sub> flooding for ASS, HT, LT panel	Provided	MR

29/ADO/MN  
22/03/2023

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide this department letter no. F6/DFS/MS/WZ/2019/2018 dated 21/10/2019, renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

DC (WEST), 868  
DATED. 23/3/2023

~~DO (West)~~

~~[Signature]~~  
23/3

~~DO (DPS)~~

~~[Signature]~~  
23/3/2023

~~CAF~~  
29/03/2023

~~Director~~  
31/03/23

~~[Signature]~~  
22/3/2023

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (MN)

~~[Signature]~~  
ADO MN