

C-80

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2023/School/241

Dated: 11/04/2023

FIRE SAFETY CERTIFICATE

Certified that the building of DAV Public School Located at Sector - 06, Dwarka, New Delhi - 110075 comprised of small basement + G+3 UFS was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2017/SZ/1828, dated 18/12/2017. The premise was re inspected by the officer concerned of this department on 01/04/2023 in the presence of Ms. Monika Mehan (Principal) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from 11/04/2023 for a period of three years. In accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/04/2023 at New Delhi by.


(Atul Garg)
Director

Delhi Fire Service.

Copy to:

1. The Principal, DAV Public School Located at Sector - 06, Dwarka, New Delhi - 110075.
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

- 1 **The newly constructed Block/ Floor shall not be occupied without getting FSC from this department.**
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: DAV Public School Located at Sector - 06, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Educational (Small Basement +Ground+ 3 UFs)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/SZ/1828, dated 18/12/17
5. Fire Safety directives Letter No. : 3298-3398 dated 01/03/2011
6. Date of inspection : 01/04/2023
7. Name of the Inspecting Officer : Sh. Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side: Ms. Monika Mehan (Principal)
9. Year of Construction :
10. Applicant's letter No. : MLKDAC/Dwarka/2023/21724 dated 28/03/2023
& Email dated 06/03/2023

Total Area = 16000 sqm.
Covered Area = 6103 sqm
Class rooms = 60
No. of students = 2400

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/13, N/14 & N/15	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos.	Provided	MR
	• Basements	02 Nos.	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr each	Old case	MR(Being old case)
	• Basements	1.5 m each	Old case	MR(Being old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	4 Nos.	Provided	MR
	e. Width Of Corridor	1.56 to 2.04 m	Old case	MR(Being old case)
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c charge	Provided	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR




5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	01 no. for every 300 sq.mtrABC or CO ₂ ISI marked	Provided ABC & CO ₂ ISI marked	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 Nos. 30 mtr 05 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm 02 Nos. Required	Provided 03 Nos. Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA NA 2x450 lpm 40 mtr Required Required	NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 15,000 ltr	15,000 ltr NA NA NA Provided	NA NA NA NA MR


4/23


15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 & ABC, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2017/SZ/1828, dated 18/12/2017 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Sign of Inspecting Officer
 Name Uday Kumar Singh
 Designation ADO/DWIT


3/4/23

CFO (SZ)

3/4/2023