



c/24



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI

No: F6/DFS/MS/School/WZ/2023/245

Dated: 11/04/2023

FIRE SAFETY CERTIFICATE

Certified that the Nigam Prathibha Vidyalaya located at B-3, Raghbir Nagar, New Delhi – 110027. Comprised of Ground plus One Upper floor only, Owned/Occupier by Nigam Prathibha Vidyalaya was issued FSC vide letter No. F6/DFS/MS/WZ/2020/145 Dated: 09/04/2020. The premises was re-inspected by the officer concerned by this department on 20/03/2023 in the presence of Smt. Neerja Aggarwal (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention & fire safety requirements in accordance with Circular No. F16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/2011 issued by the Directorate of education and found that the premises is fit for occupancy class "Educational" Group B with effect from 11/04/2023 for a period of three years subject to the compliance of the conditions mentioned below:-

Issued on 11/04/2023 at New Delhi.


(Attending)
Director

Copy to

- 1 The Principal/Incharge, Nigam Prathibha Balika Vidyalaya Located at B-3, Raghbir Nagar, New Delhi – 110027.
- 2 Director of Education, Old Sectt. Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management
3. The trained staff should be available round the clock.
4. Any deviations w.r.t construction shall be verified by the concerned building sanctioning agency
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

o/c
25/04/2023

INSPECTION REPORT

1. Name & address of the building : Nigam Pratibha Balika Vidyalaya Located at B-3, Raghbir Nagar, New Delhi-110027.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2020/145 dated: 09/04/2020
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 20/03/2023
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (Moti Nagar)
8. Name and designation of officers from the building side : Ms. Neerja Aggarwal (Principal)
9. Year of Construction : 2014 (As Per Prev. Insp. report dated 16/03/2020)
10. Applicant's letter No. : Email dated 06/03/2023

* The said school building is comprised of Ground plus one upper floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Circular dated 01/03/2011/ As Per Prev. Insp. report dated 16/03/2020	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	6 mts Provided	MR
	• Gate width	Accessible	335cm Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	3	04 Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.5 mts	2x150cm, 1x122cm & 1x127cm	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	1.5 mts	233cm Provided	MR
	h. Door Size	1 mts	2x110 cm Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		N/A	N/A	N/A

53/AD/MN
22/03/2023

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC/FSC issued vide letter no. F6/DFS/MS/WZ/2020/145 Dated: 09/04/2020 renewal under DOE Circular no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Directorate of Education, Govt. OF NCT of Delhi, is recommended.

DO (WEST) - 674
DATED - 23/3/2023

~~DO (West)~~

SPP
22/3/2023

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADOMN

Sfo (DPS)
23/3

Sfo
Director
23/3/2023
ADOMN