

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2023/SZ/120

Dated 06/04/2023

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the Name & Style of M/s **Rajender 2.0** located at A-B-11, **First Floor & Second Floor**, Community Centre, Safdarjung Enclave, New Delhi in the building comprised of Basement, Ground, **Mezzanine (Closed with brick wall)** and First & Second floor owned/occupied by Ms. Sonia Dua (Partner) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 03/04/2023 in the presence of Mr. Kausal and that the premise is fit for occupancy class **Group-D Assembly Building (Restaurant at 1st & 2nd Floor only)** with effect from 06/04/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/04/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Dy Health Officer, Public Health Department, South Zone, Green Park, Delhi- 110016
(Ref. MHA Portal ID 2023022802776 dated 28/02/2023)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL /NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in in UBBL-2016) of unauthorized construction or alteration (Clause 1 4 3 of UBBL-2016), if any
6. This fire safety certificate may not in any way be treated as regularization (Clause 2 8 of UBBL-2016) of unauthorized construction or alteration (Clause 1 4 3 of UBBL-2016), if any
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry "

NIS

INSPECTION REPORT

1. Name & address of the building : M/s Rajender 2.0 located at A-B-11 FF & SF Community Centre, Safdarjung Enclave, New Delhi
2. Type of Occupancy : Assembly Building, Group-D, Eating House
3. Type of Case : New Case (Rest. at 1st & 2nd Floor Only)
4. Comprised of : B+GF+ Mezzanine (Closed with Brick Wall) + 02 Upper floor (With Height of 9.80 mtr in MHA)
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 03/04/2023
8. Name of Inspecting Officer : DO (South) & ADO (BCP)
9. Name and designation of officers from the building side : Mr. Kausal
10. Year of Construction : 2006
11. Applicant's letter No. : MHA Portal ID 2023022802776 dated 28/02/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Part IV	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9m -NA- -NA-	Provided -NA- -NA-	MR -NA- -NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02 Nos	Provided	MR
	<ul style="list-style-type: none"> • Upper Floors • Basements 	-NA-	-NA-	-NA-
	b. Width of staircases	1.5m & 1.25m	1.50m each	MR
	<ul style="list-style-type: none"> • Upper Floor • Basements 	-NA-	-NA-	-NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.50 mtr	1.50 mtr each	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	-NA- 12 ACPH	-NA- Provided	-NA- MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	Required ABC/W CO2/CO ₂ Required	06 No's 3/3/- Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel 	-NA- -NA-	-NA- -NA-	-NA- -NA-

1 C m

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Ground & Upper Floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	Required	100mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	One	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	One	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose Box 	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Head of Main pump 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Number of main pumps 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Jockey pump head 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	MR
14.	Captive Water Storage for firefighting			
	<ul style="list-style-type: none"> Underground tank capacity 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Draw-off connection 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Fire service inlet 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Access to tank 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 Lts.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication In lift Car 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Lift Signage 	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Location 	-NA-	-NA-	-NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Flow Switch Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> PA System Panel 	-NA-	-NA-	-NA-

	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:			-NA-

M/s Rajender 2.0 located at A-B-11 First Floor & Second Floor, Community Centre, Sakdaryang Enclave, New Delhi

The fire protection system provided in the building were randomly checked and found functional at the time of inspection. The Mezzanine floor is closed with brick wall and the height of the building is 9.80mtrs as undertaking / height verification certificate submitted by the management (placed opposite of file at C/39 & C/40 respectively). The height of the building as mentioned in the online reference portal is also shown 9.80 mtr. Accordingly, fire safety measures were found installed as per the requirement of bye laws.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

Handwritten signature of Sh. Manoj Kumar Sharma

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

Handwritten signature of Sh. Rajesh Kumar

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO / BCP

CFO (HQ)

Handwritten signature and date: 3/4/2023

Handwritten signature and date: 5/4/23

Handwritten text: ADO/BCP

As approved, F.S. letter is put up for your signature pl

Handwritten signature and date: 5/4/23

Handwritten initials: 1/4/23

Handwritten text: MSB, uploaded, 5/4/2023